

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

No. F6/DFS/MS/2015/

EH/52/2062

Dated:

18/11/15

FIRE SAFETY CERTIFICATE

Certified that M/s. Haldiram Marketing Pvt. Ltd. located at B-1/H-8/1, Mohan Cooperative Industrial Estate, Main Mathura Road, New Delhi-110044 comprised of stilt, ground and two upper floors was granted NOC by this department vide letter No. F.6/DFS/MS/EH/2012/700 dated 28-02-2012. The premises was re-inspected by the officers concerned of this department on 02-11-2015 in the presence of Shri S.K. Jain, General Manager and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy Class- Industrial with effect from 18/11/15 for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 18/11/15 at New Delhi by.



(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
2. The Manager, M/s. Haldiram Marketing Pvt. Ltd., B-1/H-8/1, M.C.I.E., Main Mathura Road, New Delhi-110044.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Plot No. B-1/H-8/1, M.C.I.E., Mathura Road, New Delhi -44
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2012/700 dated 28.02.2012
5. Fire Safety directives letter No : F6/DFS/MS/BP/2012/298 dated 01.02.2012
6. Date of inspection : 02-11-2015
7. Name of the Inspecting Officers : Dharpal Bhardwaj, DO (SZ), M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. S.K. Jain, Manager (Admin. & Liaison)
9. Year of Construction : 2011
10. Applicant's letter No. : nil dated 30.09.2015.

M/s. Haldiram Marketing Pvt. Ltd. comprised of stilt, ground and two upper floors

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	---	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	---	---	---
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.5 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A



4	Smoke Management System.		N/A	N/A
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	Provided	MR
5	Fire Extinguishers		Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 ABC, WCO ₂ , CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.		Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.		Provided	MR
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required Required	Provided Provided at GF N/A Provided Provided	MR MR N/A MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.		N/A	N/A
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	N/A MR N/A
11	Internal Hydrants		Provided	MR
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 01 01	Provided Provided Provided	MR MR MR
12	Yard Hydrants.		Provided	MR
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02 02	Provided Provided	MR MR
13	Pumping Arrangements.		-	-
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put 	- 2280 lpm 70 mts 01 180 lpm	- Provided Provided Provided Provided	- MR MR MR MR

	<ul style="list-style-type: none"> ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	70 mts	Provided	MR
		2280 lpm	Provided	MR
		70 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		---	---	---
		900 LPM	Provided	MR
		35 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting. Maintained by mail			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	75,000 lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 liters	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided (125 KVA)	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/2012/700 dated 28.02.2012, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.



9/11/15

DHARMPAL BHARDWAJ
Divisional Office



7/11/15

M.K.CHATTOPADHYAY
Asstt. Div. Officer (M. Rd)