

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No:

FG/DFS/MS/School/2015/W2/2069


Dated:

18/11/15

FIRE SAFETY CERTIFICATE

Certified that the building of **DAV Public School**, Located at **Ashok Vihar, Phase- IV, Delhi.110052** comprised of Ground + 02 Upper Floors (**Except 2nd Block**) owned and occupied by **DAV Public School** was issued FSC vide Letter No. **F6/MS/DFS/08/2504 Dated 03/09/2008** The premises was re inspected by the officer concerned of this department on 15/10/2015 in the presence of **Mr Ramesh Kumar (Estate Officer)** and observed that the school is running only in a single block comprised of Ground + three Upper Floors & second block is abandoned. All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises Ground + three floors only have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 18/11/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/11/15 at New Delhi.


(Santokh Singh)
Chief Fire Officer
PH 011-23414250

Copy to:-

The Principal,
DAV Public School, Located at Ashok Vihar, Phase- IV, Delhi.110052

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. 2nd Block shall not be used for school activities.

INSPECTION REPORT

1. Name & address of the building: DAV Public School, Located at Ashok Vihar, Phase- IV, Delhi.110052.
2. Type of Occupancy : Educational Two Blocks(1st Block of Ground + 3 Upper & 2nd Block Ground + 2nd upper Floor,) (Except Abandoned 2nd Block)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/082504 Dated 03/9/08
5. Fire Safety directives Letter No. : DOE Cr 262-362 Dated 17-01-2005
6. Date of inspection : 15-10-2015
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Mr. Ramesh (Estate Officer)
9. Year of Construction : 2005-06
10. Applicant's letter No. : DAVPSAV/PH-IV/7876 dated 07-09-2015

Total Area = 1.5acre (6069.66 sqmt) Covered Area = 4903.53 M ² (all floor). Class rooms = 55 No. of students = 2450

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 262-362 Dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 X 1.5m	2x136 cm	MR(Being Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1x1 m	Provided(110 cm)All the class Room Having less than 45 students	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	18 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR
		2	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box			
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
		NA	NA	NA
	• Hose Box			

M6

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratories ; NA
3. Electric wiring ...canceled Wiring...MCB and ELCB
Electric circuit
4. Electric meter board not under the staircase
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. boardDisplayed...
7. Generator set NA

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2008/2504 Dated 03-07-2008 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended. *4/10*

Note;-Earlier the school building was comprising Two Blocks (1st ground plus three upper floors & 2nd Blocks ground plus two upper floors) now the 2nd blocks has abandoned and not being used for school activities.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Udai Vir Singh
20/10/15

Name

Udai Vir Singh

Name

Designation

AOO/WP

Designation