

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001

No. F6/DFS/MS/2015/W2/2069

Dated: 19/11/15

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation** located at **Rajouri Garden Metro Station New Delhi** comprised of Basement + Ground + Concourse + Platform (**Except PD Area**) was issued FSC vide Letter No. F6/DFS/MS/2011/27 Dated 07-01-2011. The premises was re inspected by the officers concerned of this department on 16-10-2015 in the presence of Mr. Vikas (Assistant Manager (Fire) - DMRC) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D Sub Division D - 7 with effect from 19/11/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 19/11/15 ..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer,  
Ph: 011 - 23414250.

Copy to:

1. Sh. Rajesh Agrawal (Sr. DGM/E&M),  
Metro Bhawan, Fire Brigade Lane,  
Barkhamba Road, New Delhi - 110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per BBL - 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

### INSPECTION REPORT

1. Name & address of the building: Rajouri Garden Metro Station (Except PD area)
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Basement + Ground + Concourse + Platform)
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/27 Dated 07-01-2011
5. Fire Safety directives Letter No. :
6. Date of inspection : 16-10-2015
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer  
from the building side : Mr. Vikas (Assistant Manager (Fire) – DMRC)
9. Year of Construction : 2005
10. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2015/31 Dated 08-09-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	On Main Road	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Old Case	Old Case	MR
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	Required	Safety glass found provided	MR
	• Sealing of electrical shafts	Required	Found Provided	MR

	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Found Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	35 nos. CO <sub>2</sub> & WCO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	2 on each platform 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Smoke Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	150 mm 3 on each platform Required	New Fire Pipe Line work completed Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	2 Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> </ul>	All the pumps are connected with generator also		
		1800lpm	Provided	MR
		60m	Provided	MR
		1	Provided	MR
		180lpm	Provided	MR
		60m	Provided	MR
		1800lpm	Provided	MR

	Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	10,000ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO <sub>2</sub> flooding for ASS, HT, LT panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/27 Dated 07-01-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Mukesh Verma

Name

Designation

ADD(MN)

Designation