

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No.

F6/DFS/MS/ND2/2016/1643

Dated:

08-11-16

FIRE SAFETY CERTIFICATE

Certified that the Hira Sweets Manufacturing pvt ltd., Plot no 440 FIE Patparganj Industrial area Delhi-92. being run at basement, ground plus one upper floor of the building was granted NOC by this department vide letter no. F6/DFS/MS/BP/97/302 Dated-19.03.1997. The premises was re-inspected by the team of officers of this department on dated 28.10.16 in the presence of Sh.Kiranpal Singh (Manager) have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and found that the premises is fit for occupancy Group G-1 (Industrial Building), with effect from08-11-16 for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....08-11-16.....at New Delhi by


(Vipin Kental)

Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Dy. Health Officer,
East Delhi Municipal Corporation, Health Department,
KarkardoomaSouth Zone, Shahdara, Delhi
2. Kiranpal Singh (Manager)
Hira Sweets Manufacturing pvt ltd., Plot no 440
FIE Patparganj Industrial area, Delhi-92.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- 1 Name & address of the building : Hira Sweets Manufacturing Private Ltd. Plot No.440, FIE, Patparganj, Industrial Area, Delhi-92.
- 2 Building is comprised of : Basement, Ground + One upper floor.
- 3 Type of Occupancy : Industrial
- 4 Type of Case : Renewal
- 5 Details of Previous NOC letter : F.6/DFS/MS/BP/97/302 Dated 19/03/1997
- 6 Fire Safety direction letter No : NBC Part- IV
- 7 Date of Inspection : 28/10/2016
- 8 Name of the Inspecting officers : DO, S.K. Dua, ADO, R.K. Yadav
- 9 Name and designation of Officer from the building side : Mr. Kiran Pal Singh
- 10 Year of Construction : 1996
- 11 Applicant's letter No : letter No. Nil dated 04/10/2016

N O.	Minimum Standards on fire prevention and fire safety U/R33	NBC(Old) Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	9 Mtrs	12Mtrs.	MR
	• Gate width	N.A.	N.A.	N.A.
	• Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 No.	2 No.	MR
	• Basement	2 No.	2 No.	MR
	B. Width of Staircases			
	• Upper Floor	1.25 M	1.50 M & 1.25 M	MR
	• Basement	1.25 M	1.50 M & 1.25 M	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	1 No.	2 No.	MR
	g. Width of Corridor	1.50	1.50	MR
	h. Door Size	2.0 Mtrs	2.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	Required	Provided	MR
	• Water curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12Nos.	Provided	MR
	• types	ABC & Co2	Provided	MR
	• IS marking	ISI marked	Provided	MR

	Total numbers of each floor	100	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 No.	Provided	MR
	• Hose Box	01 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	20,000 ltrs	20,000 ltrs	MR
	➤ Draw-off connection	N.A	N.A	N.A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication in lift car	N.A	N.A	N.A
	• Firemen's grounding switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	• Total area	N.A	N.A	N.A
	• Location	N.A	N.A	N.A
19	Fire Control Room			
	• Detector system panel	N.A	N.A	N.A
	• Flow switch panel	N.A	N.A	N.A
	• PA system panel	N.A	N.A	N.A
	• Battery backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire fighting system provided in the building were tested/checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the BBL & NBC Part-IV. The NOC issued vide letter no. F6/DFS/MS/BP/97/302 Dated-19/03/1997 is recommended to Fire Safety Certificate.




Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- ADO(LN)

~~DO (ED)~~  29/10

~~DEFO (ND2)~~  1/11

25/CF/ND2
2/11/16/7/11

CFP - m. scem  1/11