

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2013/WZ/1853/1647

Dated: 08-11-16

FIRE SAFETY CERTIFICATE

Certified that the **St. Stephen School** Located at **PU Block, Pitampura, Delhi - 110034** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2013/WZ/1853 Dated 05-09-2013 was inspected by the officer concerned of this department on 20-10-2016 in the presence of Ms Yash Pal Kaur (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular Dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 08-11-16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on08-11-16..... at New Delhi by.


(Atul Garg)

Chief Fire Officer

Delhi Fire Service

Copy to: **The Principal, St. Stephen School, PU Block, Pitampura, Delhi - 110034.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01 Name & address of the building: St. Stephen School, PU Block, Pitampura, Delhi - 110034.

1. Type of Occupancy : Educational (Ground + 3 Upper Floor)
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/2013/WZ/1853 Dated 05-09-2013
4. Fire Safety directives Letter No. : DOE circular dated 01-03-2011
5. Date of inspection : 20-10-2016
6. Name of the Inspecting Officer : Udaivir singh, ADO (WP)
7. Name and designation of Officer
from the building side : Ms Yash Pal Kaur (Principal)
8. Year of Construction : 1998
9. Applicant's letter No. : FSSS-01/536 Dated 20-08-2016

No. of Students=1350
No. of class rooms=44 Plot area=7999 m²
Covered area=3369 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. dated 01-03-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12 m Provided	MR
	• Gate width	Accessible	4.8 m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	NMR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1x1.5m	1x1.37cm & 1x1.43cm	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	01.5m	2.4m	MR
	f. Door Size	1m	1.1m	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	16nos.	23 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	02 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13. Pumping Arrangements:			
<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	450 lpm	Provided	MR
	40Mtr	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14. Captive water Storage for fire fighting:			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	10,000Ltr	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
17. Standby power supply	NA	Provided	NA
18. Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2013/WZ/1853 Dated 05-09-2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

 Officer

Signature of the Inspecting

Name

Odeer Vir Singh

Name

Designation

ADOLWP

Designation

ADOLWP

Inspected 24/11/16

ADOLWP

fl speaks

26/11/16

ADOLWP / ADOLWP

spoken, Performa corrected

