

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No.: F6/MS/DFS/ 2016/1102/1621

Dated:- 02/11/2016

FIRE SAFETY CERTIFICATE


Certified that the **Commonwealth Games Village**, Residential Complex at NH -24 near Akshardham Temple, **Delhi** comprised of thirty four high-rise blocks consisting two basements, Ground/stilt plus six to eight upper floors was granted NOC vide letter no. F6//MS/DFS/2010/2020 dated 09.07.2010. The Residential complex was re-inspected by a team of officers concerned of this department on 31.10.16 in the presence of **Sh. Sanjeev Kumar** and found that the Residential Complex have deemed complied with the fire prevention and fire safety requirements in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy **Group - A "Residential"** with effect from 02/11/16 for a period of **five years**, subject to conditions printed overleaf.

Issued on 02/11/16 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Secretary, Commonwealth Games Village,
Near Akshardham, New Delhi-110092
2. M/s Emaar MGF Construction Pvt. Ltd.,
ECE House, 28 Kasturba Gandhi Marg,
New Delhi-110001.



CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time & shall not be locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. All comments/ directions of the Licensing Department shall always be permitted and followed.
5. Basements shall be used as per BBL.
6. Any deviation, with regards to construction deviation, ventilation, occupancy, structural stability, electric installation etc. may be got verified from the concerned authorities.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.

1. Name & address of the building : Commonwealth Games Village, Residential Complex at NH -24 near Akshardham Temple Delhi-110091.
2. Building is comprised of : Basement, Ground /Stilt+8 upper floors (34 Towers)
3. Type of Occupancy : Residential
4. Type of Case : Renewal
5. Details of Previous NOC letter : Letter no. F6//MS/DFS/ 2010/2020 dated 09/07/2010
6. Fire Safety direction letter No : F6/DFS/MS/BP/2007/3546 dated 22/11/2007
7. Date of Inspection : 31/10/2016
8. Name of the Inspecting officers : DO S. K. Dua & ADO R.K. Yadav
9. Name and designation of officer from the building side : Mr. Sanjeev Kumar
10. Year of construction : 2009
12. Applicant's letter No : Letter No.-Nil Dated- 26.10.2016

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement/B BL	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtr.	25 mtr.	MR
		4.5 mtr.	4.5 mtr.	MR
		06 mtr.	Provided (Hard Green)	MR (Old Case)
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	68 (two in each block)	68	MR (Old Case)
		119	103	MR (Old Case)
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.25 mtr.	1.50 m each	MR
		1.25 mtr	1.50 m each	MR
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided	MR
		Ventilated	Ventilated	MR
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	30a/c per hour	Provided	MR
		30a/c per hour	Provided	MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	1000 nos.	1200 nos.	MR
		ABC /CO ₂	ABC /CO ₂	MR
		ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01 No. each block at each floor	01 No. each block at each floor	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtr.	30 mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of main panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of repeater panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooter's location 	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	100 mm	100 mm each block	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 No.	01 No. each block	MR
	<ul style="list-style-type: none"> Hose box 	01 No.	01 No. each block	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	65 Nos.	65Nos.	MR
	<ul style="list-style-type: none"> Hose box 	65 Nos.	65 Nos.	MR
13	Pumping Arrangements. There are total three nos. of fire pump houses in the premises. Details of pumps in each pump house is as under :-			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump 	2850 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of main pump 	80 M	Provided	MR
	<ul style="list-style-type: none"> Number of main pumps 	01 No.	Provided	MR
	<ul style="list-style-type: none"> Jockey pump out put 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> Jockey pump head 	80 M	Provided	MR
	<ul style="list-style-type: none"> Standby pump out put 	2850 LPM	Provided	MR
	<ul style="list-style-type: none"> Standby pump head 	80 M	Provided	MR
	<ul style="list-style-type: none"> Auto starting /manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump house access 	Required	Provided	MR
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump 	900 LPM/on each Block	Provided	MR
	<ul style="list-style-type: none"> Head of the pump 	80 M	Provided	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	2,00,000 X 3= 6,00,000 Ltrs	Provided	MR
	<ul style="list-style-type: none"> Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	25,000 Ltrs. each tower	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift car • Firemen's grounding switch • Lift Signage 	Ventilated N/A Required Required Required	Ventilated N/A Provided Provided Provided	MR N/A MR MR MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A N/A	N/A N/A	N/A N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building Floor Plans 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. *+ statcomings communicated vide letter dt 05/11/16 have been completed*

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. Letter no. F6//MS/DFS/2010/2020 dated 09.07.2010 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

R.K. Yadav
Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- A.D.O

~~DO (ED)~~

~~DUFO (NDZ)~~

ling
01/11

1/11