

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2016 11657

Dated: 11-11-16

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Kanya Vidyalaya** Located at **Rampura, Delhi-110035** comprised of 04 Blocks **Ground+ 1Upper floor only** was issued FSC vide Letter No. F6/DFS/MS/SCHOOL/2013/WZ/796, Dated-26/08/2013. The premises was re inspected by the officer concerned of this department on 25-10-2016 in the presence of Ms. Mukta Sharma (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance Circular DOE 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 11-11-16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/11/16..... at New Delhi by.


(Atul Garg)


Chief Fire Officer
Delhi Fire Service

Copy to:

The Principal, **Govt. Sarvodaya Kanya Vidyalaya Rampura, Delhi-110035**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. All the exit route shall be kept free from any obstruction.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.dhigovt.nic.in



INSPECTION REPORT

1. Name & address of the building: **Govt. Sarvodaya Kanya Vidyalaya** Located at **Rampura. Delhi-110035.**
2. Type of Occupancy : Educational Block 04(Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/796.Dated-26/08/2013(Issued for one Block only)
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection :25-10-2016
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer
from the building side :Ms. Mukta Sharma (Principal)
9. Year of Construction : 1958
10. Applicant's letter No. :G.S.K.V/RP/16-17/619 dated -22/09/2016

| |
|-----------------------|
| No. of Students=1088 |
| No. of class rooms=32 |
| Plot area=12293sqm |
| Covered area=6030 sqm |

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 1-3-11 | Provided at site | Remarks MR/NMR |
|------|---|------------------------------|--------------------------------------|-------------------|
| 1. | Access of building | | | |
| | • Road width | Accessible | 05 mtr | MR |
| | • Gate width | Accessible | 03 mtr | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | Old BI=2 New BI=1 each | Old BI=3 New BI=1 each | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | Old BL=2x1.5cm New BL=1.5 | Old BI=3x123 cm New BI=150cm each | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | | | |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | Required | 210cm | MR |
| | f. Door Size | 1 mtr | 1 mtr Provided | MR |

| | | | | |
|-----|--|-----------------------|--------------------|----|
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 21 nos. | Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | Provided in Old BL | NA |
| | • Length of hose reel hose | NA | 30m Provided | NA |
| | • Nozzle diameter | NA | 5mm provided | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEIA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | | NA | NA | NA |

| | | | | |
|-----|--|----|----------------|----|
| | <ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | <ul style="list-style-type: none"> • Ground Level • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | 450lpm | NA |
| | ➤ Head of the pump | NA | 40m | NA |
| | ➤ Power supply | NA | provided | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | 5000l provided | NA |
| 15. | Exit Signage | NA | Provided | NA |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| | Switch | NA | NA | NA |
| | ➤ Lift Signage | | | |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

11. In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2013/WZ/796, Dated-26/08/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Kumar Singh

Name

Designation ADD W/P

Designation