

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SCHOOL/2016

/1666

Dated:

11/11/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Sr. Sec. School** Located at **Kohat Enclave(Anandvash) Delhi - 110034** comprised of Block 03 (**Ground floor Pota cabin only**) was issued FSC vide Letter No. **F6/DFS/MS/SCHOOL/2013/518, Dated-05/07/2013**, The premises was re inspected by the officer concerned of this department on **25-10-2016** in the presence of **Ms. Dr Santos Varma (Vice Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Circular DOE 3298-3398 dated 01-03-2011, and that the premises is fit for occupancy class "Educational" Group B with effect from 11/11/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...../...../..... at New Delhi by.

(Atul Garg)

Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal, **Govt. Girls Sr. Sec. School Kohat Enclave(Anandvash) Delhi - 110034.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. All the exit route shall be kept free from any obstruction.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.dhigovt.nic.in](http://www.dfs.dhigovt.nic.in)

## INSPECTION REPORT

2. Name & address of the building: **Govt. Girls Sr. Sec. School Located at Kohat Enclave(Anandwash) Delhi - 110034.**
3. Type of Occupancy : Educational Block 03 (Ground Floor Only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/518.Dated- 05/07/2013
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
7. Date of inspection : 25-10-2016
8. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
9. Name and designation of Officer  
from the building side : Ms. Dr Santos Varma (Vice Principal)
10. Year of Construction : 2009
11. Applicant's letter No. : G.G.S.S.A.V/K.L/674 dated- 02/09/2016

No. of Students= 1249
No. of class rooms= 34
Plot area=17552 sqm
Covered area=2076 sqm

S No	Minimum standards on fire prevention and fire safety U/R	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	Accessible	360 cm	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	91 cm	MR(Old case)

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	07 nos. ABC & CO <sub>2</sub> ISI marked	20 Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			NA
9.	Public Address System			NA
10.	Automatic Sprinkler System			Provided
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> </ul>	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	Provided	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2013/518, Dated-05/07/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
23/11/16

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name: Uday Vir Singh

Name

Designation: ADO (WP)

Designation

*[Signature]*  
23/11/16

Dy. PO (WZ)

*[Signature]*

Ch. West

Earlier school was running in Pata Cebra, what is the position now?

*[Signature]*  
3/11/16