

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / *School/1665*

Dated: *11/11/2016*


FIRE SAFETY CERTIFICATE

Certified that the **H D M Convent School, 1522/16,A-block, Nathu Colony, Nathu Pura, Delhi** comprised of **Ground and 02 upper floors with 08 Class rooms** owned/ occupied by **Para Medical Health care Society** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/School/2013/580 dated 19.07.2013** The premise was re-inspected by the officer concerned of this department on **27.10.2016** in the presence of **Dr. M. Zafruddin (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from*11/11/16*..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*11/11/16*..... at New Delhi


(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, H D M Convent School, 15226,A-block, Nathu Colony, Nathu Pura, Delhi.

MS

INSPECTION REPORT

1. Name & address of the building : H D M Convent School, 1522/16, A-block, Nathu Colony, Nathu Pura, Delhi.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground plus 02 upper floors)
 4. Details of previous NOC : F-6/DFS/MS/School/2013/580 Dated : 19.07.2013
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/NBC Part-4
 6. Date of inspection : 27/10/2016
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
from the building side : Dr. M. Zafruddin (Manager)
 9. Year of Construction : 2008
 10. Applicant's letter No. : HDM/01/2016 Dated: 14.09.2016
- Plot Area- 325 sq.m Covered Area:975 sq.m, class rooms -08 nos, students---375 nos

| | Minimum Standards on fire prevention and fire safety U/R 33 | Director of Education letter | Provided at site | Remarks MR/NMR |
|--------------|--|-------------------------------------|-------------------------|-----------------------|
| 1 | Access to building | | | |
| | • Road width | 6m | 06m | MR |
| | • Gate width | 4.5m | 3.1m x 2(old case) | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50m each | 1.06m each | MR(old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 02 | 02 | MR |
| | e. Width of Corridor | Required | 1.10m | MR |
| f. Door Size | 1 m | 1.04 m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |

10

N/6

| | | | | |
|----|---|-----------------|--------------------|----|
| | <ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | 30 a/c per hour | NA | NA |
| | | 12 a/c per hour | Natural Ventilated | MR |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types ISI marking | 06nos | 12nos | MR |
| | | ABC/Co2 | ABC--12 | MR |
| | | ISI Marked | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 | 01 | MR |
| | | 30m | 30m | MR |
| | | 5mm | 5mm | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |

M/S

| | | | | |
|----|---|-------------|------------|-----|
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 450lpm | 450lpm | MR |
| | | 40m | 40m | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 10,000 ltrs | 10,000ltrs | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |

M/8

| | | | | |
|----|--|-----|-----|-----|
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011/NBC Part-4, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 580 dated 19.07.2013.

AK
02/11

Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN

DO/11/20
Shykh
3.11.16

By CFO (w/2)
CFO West - [unclear]
at 11/16

[Signature]
8/11/16