

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2016 / School/wz/ 1655

Dated: 10 / 11 / 2016

**FIRE SAFETY CERTIFICATE**

Certified that Marigold Public School, Khasra No.559, Village Katewara, Delhi- 110039 comprised of Ground + One upper floor owned/occupied by that Marigold Public School was issued fire safety certificate vide letter no. F.6/DFS/MS/2012/School/4742 Dated 21/12/2012. The premises was re-inspected by the officer from this department on dated 27/10/2016 in the presence of Sh. Pardeep Vats (Manager) and observed that now building is comprised of single block, ground + two upper floors. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition and there is no additional construction. The premises have therefore deem complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and the building / premise is fit for occupancy under Education Class with effect from 10 / 11 / 2016 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10-11-16 at New Delhi by

  
(Atul Garg)  
Chief Fire Officer  
Ph: 011-23414250

*etc by*

**Copy to:**

1. The Principal, Marigold Public School, Khasra No.559, Village Katewara, Delhi- 110039.
2. The Director of Education, Old Secretariat, Delhi

**INSPECTION REPORT**

Single block  
Previous Gr.+ one upper floor  
Present - Gr.+ two upper floors

1. Name & address of the building : Marigold Public School, Khasra No.559, Village Katewara, Delhi-110039.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No.F.6/DFS/MS/2012/School/4742 Dated 21/12/2012
5. Fire Safety directives letter No : DFS Act 2007 & Rule 2010.
6. Date of inspection : 27/10/2016
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers  
from the building side : Sh. Pradeep Vats (Manager)
9. Year of Construction : 2002 & 2013
10. Applicant's letter No. : MPS/DFS/June/2016/385 Dated 10/10/2016

**Plot Area:**3622 sq m **Covered Area:**Gr. + FF-2107 & SF- 290 sq m **No. of Students:**620 **NO. of Class Rooms:** 23 + 08 room for other purpose & 03 labs

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	02	03	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	2 X 1.80 & 1.20 mtr	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	—	—	—
	h. Door Size	1.00 mtr	1.10 mtr	MR

*Sh. Pradeep Vats*

3	<b>Compartmentation.</b>	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	12 ABC	23	MR
	• Types		ABC	MR
	• IS marking	ISI marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One in each floor	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

*Alchana*

12	<b>Yard Hydrants.</b>		
	• Total number of hydrants	—	—
	• Hose Box	—	—
13	<b>Pumping Arrangements.</b>		
	• Ground Level	—	—
	➤ Discharge of main Pump	—	—
	➤ Head of Main pump	—	—
	➤ Number of main pumps	—	—
	➤ Jockey Pump out put	—	—
	➤ Jockey pump head	—	—
	➤ Standby Pump out put	—	—
	➤ Standby Pump Head	—	—
	➤ Auto Starting/ Manual stopping	—	—
	➤ Pump House Access	—	—
	• Terrace level	—	—
	➤ Discharge of pump	450 LPM	Provided MR
	➤ Head of the pump	40 M	Provided MR
	➤ Power Supply	—	—
	➤ Auto Starting of pump	—	—
14	<b>Captive Water Storage for fire fighting.</b>		
	• Underground tank capacity	—	—
	➤ Draw-off connection	—	—
	➤ Fire service inlet	—	—
	➤ Access to tank	—	—
	• Overhead Tank capacity	10,000 ltrs	Provided MR
		Required	Provided MR
15	<b>Exit Signage.</b>		
16	<b>Provision of Lifts.</b>		
	• Pressurization of Lift Shaft	—	—
	• Pressurization of Lift lobby	—	—
	• Communication In lift Car	—	—
	• Fireman's Grounding Switch	—	—
	• Lift Signage	—	—
17	<b>Standby power supply</b>		
		—	—

*[Handwritten Signature]*

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no Letter No. F.6/DFS/MS/2012/School/4742 Dated 21/12/2012. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer



Signature of the Inspecting Officer


Name

Name

Designation

Designation

  
 S Singh  
 31.10.16  
 Dy. CFO (WZ)  
  
 CFO - Alex  
 31/10/16

  
 A. K. Sharma  
 31/10/16  
 Dy. CFO (WZ)