

FORM 'H'.
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFB/MS/EN/2016/02/1652

Dated: 10/11/2016

FIRE SAFETY CERTIFICATE

Certified that the M/s Marine Drive (a unit of Jayant Hospitality Pvt. Ltd) at A-2, GF & FF, Main Najafgarh Road, Vishal Enclave, New Delhi in a comprised of Ground+01 upper floor owned/occupied by M/s Marine Drive (a unit of Jayant Hospitality Pvt. Ltd) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 04.11.2016 in the presence of Mr. Kapil Aggarwal (Partner) and that the building/premises is fit for occupancy Assembly with effect from 10/11/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/11/16 at New Delhi by


(ATO Garg)
Chief Fire Officer
Ph: 011-23414250

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used only as per NBC part-IV.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs. DelhiGovt. Nic.in](http://www.dfs.DelhiGovt.Nic.in)
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Copy to:

1. M/s Marine Drive (a unit of Jayant Hospitality Pvt. Ltd) at A-2, GF & FF, Main Najafgarh Road, Vishal Enclave, New Delhi.
2. Dy. Health Officer West Zone, Vishal Enclave, Rajouri Garden, New Delhi-110027.

INSPECTION REPORT

1. Name & address of the building : M/s **Marine Drive** (a unit of Jayant Hospitality Pvt. Ltd) at A-2, GF & FF, Main Najafgarh Road, Vishal Enclave, New Delhi.
2. Type of Occupancy : Assembly (Building comprised of G+01 upper floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 04-11-2016
7. Name of the Inspecting Officers : Mukesh Verma DO (M.N.)
8. Name and designation of officers
From the building side : Mr. Kapil Aggarwal (Partner)
9. Year of Construction : 2005
10. Applicant's letter No. : D-2467/HD/WZ dated 27/07/16

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	M/R
	• Gate width	4.5 mtr	Provided on main road	M/R
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1 mtr	1.5 mtr & 1 mtr Provided	M/R
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	02	02 Provided	M.R.
	e. Width of Corridor	NA	NA	NA
	f. Door size	2 mtr & 1 mtr	2 mtr & 1.5 mtr Provided	M.R.
3.	Compartmentation.			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	06	08	M.R
	• Types	DCP & CO ₂ type	Provided	M.R

[Signature]

	• IS marking	ISI marked	Provided	M.R
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.A.	Provided	N.A.
	• Location of Main Panel	N.A.	Provided	N.A.
	• Location of Repeater Panel	N.A.	Provided	N.A.
	• Alternate source of power	N.A.	Provided	N.A.
	• Hooter's Location	N.A.	Provided	N.A.
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.A.	Provided	N.A.
	• Sprinkler above false ceiling	N.A.	N.A.	N.A.
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	M.R
	• Number of hydrants per floor	01	01 Provided	M.R
	• Hose Box	01 Required	01 Provided	M.R
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.

2/9/17

14.	Captive Water Storage for fire fighting			
	Underground tank capacity	N.R.	N.R.	N.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R	N.R	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Name : Mukesh Verma

Designation DO (W)

Mukesh Verma
4/11/16

[Signature]
4/11/16

[Signature]