

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2016/ND2/1170

Dated: 15/11/16

FIRE SAFETY CERTIFICATE

Certified that the Plot no. 82, FIE Patpargang, Industrial area Delhi-92, owned/occupied by Toyo Ink India Pvt. Ltd. Comprised of basement, ground plus one upper floors of the building was granted NOC by this department vide letter no. F6/MS/DFS/96/1132 Dated-17/09/96. The premises was re-inspected by the concerned of this department on dated 27/09/16 & 24/10/16 in the presence of Smt..Sharda Jha (Manager) and found the premise is comprised of basement, ground plus two upper floors have deemed complied with the fire prevention and fire safety requirements in accordance with BBL & NBC Part-IV and found that the premises is fit for occupancy Group "G (Industrial Building)", with effect from 15/11/16..... for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 15/11/16..... at New Delhi by

15/11
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
The Excutive Engineer (Bldg.)HQ,
East Delhi Municipal Corporation,
Udyog Sadan, Patpargang, Industrial Area Delhi-92.
Copy to-

Smt..Sharda Jha (Manager),
Plot no. 82, FIE Patpargang, Industrial area Delhi-92

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Plot no. 82, FIE Patpargang, Industrial area Delhi-92.
2. Building is comprised of : Basement, Ground+2 Upper floors
3. Type of Occupancy : Industrial
4. Type of Case : Renewal/Additional & Alteration
5. Details of Previous NOC : F6/DFS/MS/96/1132 Dated 17/09/96
(for basement,G+1)
6. Fire Safety direction letter No : F6/DFS/MS/96/1056 Dated-30/08/96
7. Date of Inspection : 27/09/16 & 24/10/16
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer
from the building side : Smt.Sharda Jha (Manager)
10. Year of Construction : 1996
11. Applicant's letter No : dated 01/09/16

S. N	Minimum Standards on fire prevention and fire safety U/R33	BBL/NBC Part-IV	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	12 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 nos.	2 nos.	MR
	Basement	1 no.	1 no.	MR (Old accepted)
	b. Width of Staircases			
	Upper Floor	1.5 & 1.25 m	1.5 & 1.25 m	MR
	Basement	1.25 m	1.25 m	MR (Old accepted)
	c. Protection of exits			
	Fire check door	Required	provided	MR
	Pressurization	Required	provided	MR
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	Fire check door	Required	provided	MR
	Sealing of electrical shafts	Required	Sealed	MR
	Fire rating of shaft door	02 hrs.	02 hrs.	MR
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Required	provided	MR
	Upper floor	N.A.	N.A.	N.A.
5	Fire Extinguisher			
	Total numbers	40 nos.	40 nos.	MR
	types	CO ₂ & ABC	provided	MR
	IS marking	ISI marked	provided	MR

Earlier NOC issued vide letter no. F6/DFS/MS/96/1132 dt. 17/09/96.

115


6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	Heat & Smoke	MR
	Location of main panel	Security Room	Provided	MR
	Location of repeater panel	Security Room	Provided	MR
	Alternate source of power	Battery & DG Set	Provided	MR
	Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	basement	Required	provided	MR
	upper floor	Required <i>Required</i>	provided	MR
	sprinkler above false ceiling	N.A.	provided	MR
11	Internal Hydrants			
	size of riser/down-comer	N.A.	Provided	MR
	Total no. of hydrants each floor	N.A.	Provided	MR
	Hose Box per floor	N.A.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	10 Nos.	MR
	Hose Box	N.A.	10 Nos.	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		N.A.	N.A.	N.A.
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	provided	MR
	Access to tank	Required	provided	MR
	Overhead Tank capacity	10,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/G

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	provided	MR
	Flow switch panel	N.A.	provided	MR
	PA system panel	N.A.	provided	MR
	Batter backup	N.A.	provided	MR
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire extinguishers provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the BBL & NBC Part-IV. The NOC issued vide letter no. F6/MS/DFS/96/1132 Dated-17/09/96 is recommended to Fire Safety Certificate.



Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- ADO (LN)

DO(ED)

Signature
27/10

DFD(ND2)

Signature
28/X