

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/FW/2016/WZ/1171

Dated: 17/11/16

FIRE SAFETY CERTIFICATE

Certified that the **M/s Ram Dass Traders** (Prop. Smt. Ravinder Kaur) located at Ground Floor Shop No. 2, MCD Market, Tagore Garden, New Delhi – 110027 in a building comprised of Ground plus one upper floor was issued FSC vide Letter No. **F6/DFS/MS/20103/FW/WZ/706** dated 13/08/2013. The premises was re inspected by the officers concerned of this department on 31-10-2016 in the presence of **Mr. Dalbir Singh** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" Group J with effect from 17/11/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/11/16 ..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Following fire safety directives must be adhered to:

1. All the means of escape/ entry/ exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/ equipment non functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The NOC is for fireworks at Ground Floor only.

Copy to:

1. M/s Ram Dass Traders Prop. Smt. Ravinder Kaur,  
E-241, 3<sup>rd</sup> Floor, Tagore Garden,  
New Delhi – 110027.

INSPECTION PERFORMA (PART - B)  
(TO BE FILLED IN TRIPLICATE BY THE INSPECTING OFFICER)

DATE:

TIME:

S.NO.	POINT OF INSPECTION	NORM AS PER GUIDELINES/ VR COMMITTEE REPORT	REMARKS OF THE INSPECTING OFFICER
1.	Type of construction and floor area and floor level	1. Minimum floor area 9 m <sup>2</sup> 2. Pucca construction 3. Premises not under staircase/ means of exit 4. Business permissible only at ground floor 5. Business from pavement of road prohibited	Provided Provided Complied Yes, at ground floor Complied
2.	Entrance & exit to the licensed premises	The licensed premises shall have independent entrance and exit	Provided
3.	Type and distance of surrounding risk	The premises shall be situated at a distance of 15m from any such premises used for similar exclusive/ inflammable or hazardous materials	No other premises of some type/business
4.	Nature of business run in the licensed premises	The premises in which fire works are kept shall be used only for possession and sale of fire works and no other purpose	Only for fire works
5.	Type of Electrical wiring and electrical fittings	1. Preferably concealed or through conduit 2. The electrical fittings should be flame/ spark proof	Provided Provided
6.	Extension of shop for business	prohibited	No other business
7.	Approach road	The road width on the sides of which premises is located should be 12m	Provided
8.	Fire Protection arrangements 1. Extinguishers (type & no.) 2. Sand/ Water buckets 3. Water Drum	1. All the extinguishers shall have ISI mark 2. No. of fire extinguishers & type shall be in accordance with the risk & area of the premises 3. Minimum 2 buckets each of sand & water shall be provided	Provided ISI Mark CO <sub>2</sub> 4.5 kg (2 nos.) WCO <sub>2</sub> 9 ltrs cap. (2 nos.) ABC 5 kg cap. (2 nos.) Provided 2 buckets of sand & water each
9.	Any other point that is contrary to the safety of people		No other business is allowed

*Pl Mark*

*Dy. Insp. W-2*

*DO/N*

*spoken on 8/11/16*

*Inspector 8/11/16*

*[Signature]*  
Signature of Inspecting Officer  
DO (West) Designation



GRANT OF NOC FOR SALE/ STORAGE OF FIRE WORKS  
(In areas other than walled city and congested areas)  
INSPECTION REPORT (PART - A)  
(To be filled by the Inspecting Officer)

1. Name and Address of the license : **Smt. Ravinder Kaur R/o E-241, 3<sup>rd</sup> Floor, Tagore Garden, New Delhi – 110027.**
2. Address of the licensed premises: premises: **M/s Ram Dass Traders** (Prop. Smt. Ravinder Kaur) located at Ground Floor Shop No. 2, MCD Market, Tagore Garden, New Delhi – 110027
3. License No. and **Renewal**  
validity period: **3 years**
4. Authority by which FSC vide Letter No. **F6/DFS/MS/20103/ FW/WZ/706 dated 13/08/2013**  
license was issued  
last:
5. Name and Designation **Mukesh Verma**  
of the Inspecting Officer: **(DO West)**
6. Date and time **31.10.2016 15.30 hrs.**  
of inspection:
7. Period for which license **3 years**  
is to be renewed  
the authorized quantity:
8. Recommendations of FSC is recommended is **M/s Ram Dass Traders, Shop No.2, MCD**  
the inspecting officer **Market, Tagore Gargden, New Delhi-110027.**  
for issue/ rejection of  
NOC with reasons:

Remarks of DO (West)

Remarks of DCFO

Remarks of CFO

  
(Signature of Inspecting Officer)  
Designation DO (West)

Issue NOC/ Reject

\*NOC is issued subject to the condition that status quo shall be maintained and the conditions laid down under Indian Explosives Rules 1983/ conditions laid down by MCD/ Police are complied with.

Dated:

  
Chief Fire Officer,  
Delhi Fire Service.

*F.T. letter is put up for signature please.*

*Mukesh*  
*CFO (West)*  
*Mukesh*

*16/11/16*

*Mukesh*  
*15/11/16*