

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/School/2016/SZ/ 1184

Dated: 23/11/16

FIRE SAFETY CERTIFICATE

Certified that the Divinity International Pre School, located at Plot No. A, NSI, Pkt- HAF, Sector-22, Dwarka, New Delhi, comprised of ground plus two upper floors owned/occupied by Favourite Education Society was granted NOC vide this department letter no. F6/DFS/MS/2007/3459 dated 13.11.2007. The premises was re-inspected by the officer concerned of this department on 27.10.2016 in presence of Sh. Harshit (Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service and that the premises/building is fit for occupancy class B "Educational building" with effect from ~~23/11/16~~-----for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule, 2010, printed overleaf.

Issued on ~~23/11/16~~..... at New Delhi by


(Vipin Kental)
D/C Chief Fire Officer


Copy to:

1. The Dy. Director, (Education), G.N.C.T.Of Delhi, Old Secretariat, New Delhi.
2. The President, Favourite Education Society KG-III/54, Vikas Puri, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Divinity International Pre School (Favourite Education Society) Plot No.A, NSI Pkt. HAF, Sector-22, Dwarka, New Delhi.		
2	Type of Occupancy	Educational Building "B" Ground + Two upper floor		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2007/SZ/3459 Dated 13.11.2007		
5	Fire safety directives letter No	Dir. Edu. Circular. No. 262-362 dated 17.01.2005		
6	Date of inspection	27.10.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Harshit (Manager)		
9	Year of construction	2007		
10	Applicant's letter No.	JBMPS/16/Fire/1 dated 20.8.2016		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Fire Safety Requirements as per letter dated 13.11.2007	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A.	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 & 1 Mtrs.	1.5 & 1 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	1.50 Mtr.	1.46 Mtrs.	MR being old case
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A

5	Fire Extinguishers			
	total numbers	2 Nos. each floor	7 Nos.	MR
	Types	Co2,ABC ISI Marked	CO2 & ABC	MR

6	First-Aid Hose Reels.	One	One	MR
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public Address System.			
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	100 mm	MR
	Number of Hydrants per floor	One	One	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 LPM	450 & 180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/5

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire Extinguisher Provided near MR Electric Meter.			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2007/3459 dated 13.11.2007 is recommended under Rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Sury 27/8/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)



D/SW

[Signature]
27/10/16

DCFO (SZ)

[Signature]
4/4