

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/GH/2016/W2/1198

Dated: 24/11/16

FIRE SAFETY CERTIFICATE

Certified that the **M/s Blessing Guest House** Located at **Plot no – 4, LSC at Junction of 80 Wide Road, Pitampura Delhi – 110034** at Ground, 1st, 2nd & 3rd Floor in a building comprised of Basement + Ground + 3 Upper Floors) (Total 18 Rooms) (Basement-not in use/sealed, Ground Floor-Lobby, 1st, 2nd & 3rd Floor- Six Room at each floor) owned/ occupied by **M/S Blessings Guest House** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 11-11-16 in the presence of **Mr Saurav vij** (Owner) and found that and found that the said building that the premises is fit for occupancy class “Residential Building” **Group A of Sub Division - A 1** with effect from 24/11/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24.11.16..... at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to: 1. **Joint CP(Licensing Unit), 1st Floor, PS Defence Colony, New Delhi**

2. **Dy Health Officer, Public Health Department, Rohini Zone, Sector -5, Rohini, Delhi- 110085**

3. **Sh Saurav Vij, Blessing Guest House, Plot no – 4, LSC at Junction of 80 Wide Road, Pitampura Delhi – 110034.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall not be used as undertaking given by owner.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Blessing Guest House** Located at **Plot no – 4, LSC at Junction of 80 Wide Road, Pitampura Delhi – 110034.**
2. Type of Occupancy : Residential (**Guest House at Ground ,1st , 2nd & 3rd Floor in a building comprised of Basement + Ground + 3 Upper Floors**)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 11-11-2016
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Saurav Vij
9. Year of Construction :
10. Applicant's letter No. : DHO/RZ/2016/783 dated 11-07-2016 & letter received on 18-10-2016

Total Room =18

Ground Floor= Lobby
1st, 2nd & 3rd Floor= Six
Room at each Floor -

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	Accessible	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA(closed not in use)	1 provided	NA
	b. Width of staircases			
	• Upper floors	1X1.2 m & 1x1.5m	Provided 1X125cm & 1x1.5m	MR
	• Basements	NA	1x1.2m	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtrs	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System	Basement not in use		
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust Fan Provided	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	08 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mtrs	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	Provided	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	Provided	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450lpm	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5000 ltrs	Provided (10,000 Ltrs)	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	<i>Lift run from GF to 3rd Floor.</i>		
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--------------------------------------------------------------------------	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

Signature of the ~~Inspecting~~ Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation AO/WP

Designation

DO/W 15/11/16

By: UVO (W2) Take the undertaking for basement fan closed/ sealed.

17/11/16

DO/W / ADO

Sir, Undertaking placed at C/4 of the basement is not being used for any purpose.

Dy. AO
AO - West

17/11/16

17/11