

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2016/1213

Dated: 25.11.2016

FIRE SAFETY CERTIFICATE

Certified that the **Ravi Kishore Enterprises Pvt. Ltd.** Located at **B-12, Lawrence Road Industrial Area, New Delhi-110035** in a building comprised of Lower Basement + Upper Basement + Ground Floor +Mez Floor + First Floor & Second Floor, owned/ occupied by **Ravi Kishore Enterprises Pvt. Ltd.** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 15-11-2016 in the presence of Sh. Kishore Arora (Partner) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 25.11.2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25.11.2016 at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to: **Ravi Kishore Enterprises Pvt. Ltd**
B-12, Lawrence Road Industrial Area, New Delhi-110035.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per BBL1983
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
10. The FSC issued vide this office letter no F-6/DFS/MS/2016/WZ/1208 dated 28/07/2016 shall be stand cancelled.



Re inspection to include the Mezzanine Floor in the FSC issued on 28/07/2016

INSPECTION REPORT

1. Name & address of the building: **Ravi Kishore Enterprises Pvt. Ltd.** Located at **B-12, Lawrence Road Industrial Area, New Delhi-110035.**
2. Type of Occupancy: Banquet, (L. Basement + U Basement + Ground Floor + Maz Floor + First Floor & Second Floor Only).
3. Type of Case : *Renewal*
4. Details of previous NOC ; F-6/DFS/MS/2016/1208 dated 28/07/2016(sealed Mez. Floor)
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2014/43 Dated 24/01/2014
6. Date of inspection : 15-11-2016
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer from the building side : Sh. Kishore Arora (Partner)
9. Year of Construction : 2015-16
10. Applicant's letter No. : Nil Dated – Nil

Basement=Parking
 Banquet=At Ground, 1st & 2nd Floors
 Mezzanine Floors= Bridal Room
Offices,

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 m 6m NA	Provided Provided (On open Road) NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2 2	2 Provided 2 Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2x2 m M.F=1x2m&1x1m 2x2 m,& Ramp 2x450cm	FF & SF=1x200 cm & 1x205 cm Mez F=1x2m & 1m 1x200 cm & 1x205 cm & Ramp 2x450cm	MR MR
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2m & 1x1m for office at mez floor	GF=2x220cm,1x210cm&1x214cm Mez=2x105cm(office) FF=1x220cm&1x210cm 2 nd F=1x220cm&1x210cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Dampers 	Required	Provided	MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30a/c per hrs	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	35	35 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO2 & WCO2	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	2	2 Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	36 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2	2 Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	6	6 Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	6	6 Provided	MR

13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 lpm	2280 lpm Provided	MR
		70 m	70m Provided	MR
		1	Provided	MR
		180 lpm	180 lpm Provided	MR
		70 m	70m Provided	MR
		2280 lpm	2280 lpm Provided	MR
		70 m	70 m Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450lpm	45 lpm Provided	MR
		40m	40 m Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank cpty 	1,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided	MR
----	--	----------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. **F6/DFS/MS/2016/1208 Dated 28/07/2016** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- **Earlier FSC was issued with sealed Mezzanine Floor due to availability of one staircase. Now the party have provided two stair case for mezzanine floor.**

Signature of the Inspecting Officer *[Signature]* 28/07/16

Signature of the Inspecting Officer

Name *Uday Kir Singh*

Name

Designation *ADD/WP*

Designation

DD/CO

[Signature] 17/11/16

DD/CO (W2)

[Signature] 17/11/16

Cfo. West-44
18/11/16
[Signature]

whenever both of staircase found out by party at mezzanine floor

[Signature]
18/11/16