

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/BNQT/2016/NDZ/ 1206

Dated: 25/11/16

FIRE SAFETY CERTIFICATE

Certified that the Shubh Milan Banquet Hall is running at first & second floor of building comprised of ground plus two upper floors at 534, 534/4, 534/5 Jheel Khuranja, Delhi -51, have complied with the fire prevention and fire safety requirements and verified by the officer concerned of this department on 10/11/16 in the presence of Mr. Tilakraj (Manager) of the Banquet Hall and found that the first & second floor building is fit for occupancy class "D" 'Assembly Building' with effect from 25.11.16.. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....25.11.16.....at New Delhi by


(Vipin Kental)
Chief Fire Officer

ok

PS

To,

Manager,
Shubh Milan Banquet Hall,
534,534/4,534/5 Jheel Khuranja,Delhi -51.

Copy to:-

1. The Deputy Health Officer (EDMC),
SHD (N)-Zone, Health Department,
Delhi-110032

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Shubh Milan Banquet Hall,534,534/4,534/5 Jheel Khuranja,Delhi -51.
2. Building is comprised of :G+2 (Banquet hall running at IST & IIND floor only)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : BBL
7. Date of Inspection : 10/11/16
8. Name of the Inspecting Officers: : ADO R.K.Yadav
9. Name of the designation of Officer from the building side : Mr.Tilakraj (Manager)
10. Year of Construction : 1985
11. Applicant's letter No : dated 19/10/16

S. No	Minimum Standards on fire prevention and fire safety U/R33	BBL 1983	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	06 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	N.A.	N.A.	N.A.
	b. Width of Staircases			
	Upper Floor	1.5 m	1.8 m & 1.5 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	Required	provided	MR
	Pressurization	Required	provided	MR
	e. No. of continuous staircases to terrace	1 no.	2 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. No. of door	N.A.	N.A.	N.A.
	i. Door Size	2 m	2 m	MR
3	Compartmentation.			
	Fire check door	Required	provided	MR
	Sealing of electrical shafts	Required	provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Ventilated	Provided	MR
5	Fire Extinguisher			
	Total numbers	10 no.	Provided	MR
	Types	CO ₂ & ABC	Provided	MR
	IS marking	ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Total no. of hydrants each floor	1 no.	Provided	MR
	Hose Box per floor	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> ● Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> ● Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	450 Lpm	900Lpm	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 Liters	Provided	MR

116

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire extinguishers provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the BBL it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
12/11/2012

Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- ADO (LN)

Line
DO(ED) 16/11

DeFO(NDS)
21/11