

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/2016/ 1196

Dated: 24/11/16

FIRE SAFETY CERTIFICATE

Certified that the **The Irish House, situated at R-02, UGF, TDI (Epicuria) Mall, Nehru Place Metro Station, New Delhi-110019** comprised of Basement, Lower Ground floor & Upper Ground Floor, but the Restaurant is running on Upper Ground Floor only. The premise was inspected by the officer concerned of this department on **12/11/16** in the presence of **Mr. Mohit (Manager)** and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group- D Assembly "Eating House"** with effect from ~~24/11/16~~ 24/11/16---2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.... 24/11/16 .....at New Delhi by.

W  
24/11  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to:-

1. Jt. C. P. (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi
2. Sh. Ashish Chavan, M/s The Irish House, R-02, Upper Ground Floor, TDI (Epicuria) Mall, Nehru Place Metro Station, New Delhi-110019

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

**INSPECTION REPORT**

1. Name & address of the building: The Irish House, R-02, UGF, Epicuria Mall, Nehru Place Metro Station, New Delhi-110019
2. Type of Occupancy : Group D Assembly Building (Eating House)[Building is B+LG+ UG]
3. Type of Case : New[Restaurant at Upper Ground Floor only]
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 12/11/2016
7. Name of Inspecting Officer : A.K. Malik
8. Name and designation of officers  
From the building side : Mr. Mohit (Manager)
9. Year of Construction : 2016
10. Applicant's letter No. : 4291/Jt. C. P./Lic/EH(DA-I)/New Delhi dated 19/10/16

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b> [TDI Mall FSC No. of F6/MS/DFS/SZ/2016/743 dated 10/05/16]			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restaurant within Mall	As Above	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b> [Provided & Maintained by Mall management]			
	a. Number of staircases	Restaurant within Mall	As Above	MR
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Restaurant within Mall	As Above	NA
	b. Width of staircases	Restaurant within Mall	As Above	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	Restaurant within Mall	As Above	NA
	c. Protection of exits	Restaurant within Mall	As Above	NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	2m	2m & 1.25m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
4.	<b>Smoke Management System</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 ACPH	As Above	NA
		12 ACPH	Exhaust Fan	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	6 No's ISI marked	7 Nos	MR
			ABC-5No's	MR
			CO <sub>2</sub> -2 No's	MR
6.	<b>First-Aid Hose Reels</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One (Near to Restaurant) 30 m 5 mm	As Above	MR
			As Above	MR
			As Above	MR
7.	<b>Automatic fire detection and alarming system</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA NA NA NA NA	As Above	NA
			As Above	NA
			As Above	NA
			As Above	NA
			As Above	NA
		Required	Provided	MR

	• Ground Floor	NA	As Above	NA
	• Sprinkler above false ceiling	NA	As Above	NA
<b>11.</b>	<b>Internal Hydrants</b> [Provided & Maintained by Mall management]			
	• Size of riser/down-comer	100mm	As Above	MR
	• Number of hydrants per floor	One (near to Restaurant)	As Above	MR
	• Hose Box	One (near to Restaurant)	As Above	MR
<b>12.</b>	<b>Yard Hydrants</b> [Provided & Maintained by Mall management]			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
<b>13.</b>	<b>Pumping Arrangements</b> [Provided & Maintained by Mall management]			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	[Provided & Maintained by Mall management]		
	➤ Discharge of pump	450 LPM	As Above	MR
	➤ Head of the pump	40 M	As Above	MR
	➤ Power Supply	Required	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
<b>14.</b>	<b>Captive Water Storage for firefighting</b> [Provided & Maintained by Mall management]			
	• Underground tank capacity	NA	As Above	NA
	➤ Draw-off connection	NA	As Above	NA
	➤ Fire service inlet	NA	As Above	NA
	➤ Access to tank	NA	As Above	NA
	• Overhead Tank capacity	10,000 Lts	As Above	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b> [Provided & Maintained by Mall management]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area.</b> [Provided & Maintained by Mall management]			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
<b>19.</b>	<b>Fire Control Room</b> [Provided & Maintained by Mall management]			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

-N/U-

The Irish House, R-02, UGF, Epicuria Mall, Nehru Place Metro Station, New Delhi-110019  
Accordingly FSC in shape of DFA is put up for approval.

*Amitabh*  
15/2/16

Signature of Inspecting Officer

Name:- A.K. Malik

Designation:- DO (SZ)

Dy. CFO (SZ)

*camp*  
15/11

*CF (SZ)*

m'scell

FT b1.

*W*  
22/11

Sir, F.T. is put up for sig. please.

*Amitabh*  
25/2/16

*CF (SZ)*

m'scell

*W*  
24/11



*401 CFO SZ*  
*23/11/16*