

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO.F6/DFS/MS/Workshop/2016/ W2/1214

DATED: 28/11/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Galaxy Automobiles Pvt. Ltd. at Property No. 28, DLF Industrial Area, Near Moti Nagar, New Delhi, comprised of three basement, ground plus two upper floors owned/occupied by M/s Galaxy Automobiles Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 16.11.2016 in the presence of Sh. S.M. Mathur (Vice President), of the workshop and that the building is fit for occupancy class-H "Storage Building-(Workshop)" with effect from 28/11/16.... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to the conditions mentioned below.

Issued on 28/11/16..... at New Delhi by


Atul Garg
Chief Fire Officer
(011-24314250)

Copy To:-

1. Sh. S.M Mathur (Vice President) the M/s Galaxy Toyota (A Unit of Galaxy Automobiles Pvt. Ltd.) TSG complex, 69/1-A, Najafgarh Road, Moti Nagar, New Delhi-110015.
2. The Executive Engineer (B), North Delhi Municipal Corporation, Karol Bagh Zone, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Galaxy Automobiles Pvt. Ltd. at Property No. 28, DLF Industrial Area, Near Moti Nagar, New Delhi.		
2	Type of Occupancy	Storage Occupancy (Workshop)		
	Buiding comprised of	Three basement, ground plus two upper floors		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	F6/DFS/MS/BP/2012/3468 dated 21.09.2012		
6	Date of inspection	16.11.2016		
7	Name of the inspecting Officers	Dcfo Dharampal Bhardwaj & DO Mukesh Verma		
8	Name and designation of officers	Sh. S.M. Mathur (Vice President)		
	from the building side			
9	Year of construction	2016		
10	Applicant's letter No.	Nil, Dated 30.09.2016		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	12 Mtr	12 Mtr Provided	MR
	2) Gate width	5 Mtr	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos. Provided	MR
	2. basements	2 Nos.	2 Nos. Provided	MR
	b. Width of staircase			
	1. Upper floors	1.5 Mtr	1.5 Mtr each Provided	MR
	2. basements	1.5 Mtr	1.5 Mtr each Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	2 Nos.	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	Provided	MR
	upper floors		Provided	MR

(N)

5	Fire Extinguishers			
	total numbers	45	55 Nos. Provided	MR
	Types	ABC CO2	Provided	MR
	ISI marking	Yes	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	Two	Two Provided	MR
	Length of Hose reel hose	30 Mtr	30 Mtr Provided	MR
	Nozzle Diameter	5mm	5 MM Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Smoke & Heat	Provided	MR
	location of Main Panel	Required	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	Required	All Areas	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	Two	Two Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	Required	Provided	MR
	house box	Required	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2850 LPM	2850 LPM Provided	MR
	b. Head of main pump	60 Mtr	60 Mtr Provided	MR
	c. Number of main pumps	One	One	MR
	d. jockey pump out put	180 LPM	180 LPM Provided	MR
	e. jockey pump head	60 Mtr	60 Mtr Provided	MR
	f. Standby Pump output	2850 LPM	2850 LPM Provided	MR
	g. Stanby Pump head	60 Mtr	60 Mtr Provided	MR
	h. Auto Starting/Manual stopping	Required	Both Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	40 Mtr	40 Mtr Provided	MR
	c. Power supply	Required	Provided	MR

14	Captive water storage for fire fighting			
	1. Underground tank capacity	1,00,000 ltr	1,00,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	d. Over head tank Capacity	10,000 ltr	10,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.	Lift lobby & Mechanical lift are provided as per sanctioned plan vide letter no. 872/Reg./R/KB2/2015 dated 26.9.2015 and covering letter no. D/AE(B)/KBZ/2015/7711 dated 18.11.15 by NMCD (Karol Bagh Zone)		
	a. Pressurization of lift shaft	Required	Provided	MR
	b. Pressurization of lift lobby	Required	Provided	MR
	c. Communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A	N/A	N/A

The Shortcomings issued vide letter no.F6/DFS/MS/2016/1632 dated 01.07.2016 found complied.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer
Name Dharampal Bhardwaj
Designation:- DCFO (West Zone)

Signature of the Inspecting Officer
Name Mukesh Verma
Designation DO (West)

CEO (WZ) *Mark* what about pressurized