

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2016/ *w2/1210*

Dated: *25/11* /2016

FIRE SAFETY CERTIFICATE

Certified that the **Party Place Banquet** located at **B-2 Lawrence Road Ind. Area, Delhi.** comprised of Ground Floor + Two UFs was issued FSC vide Letter No. **F6/DFS/MS/2011/1091 Dated 03/06/2011.** The premises was re inspected by the officer concerned of this department on 11/11/2016 in the presence of Sh. Sunil Puri (Banquet Staff) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance that the premises is fit for occupancy class "Assembly" Group D with effect from *25/11/16* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

**Sh Sanjeev Verma,
B-2 Lawrence Road Ind. Area, Delhi**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its

2. Name & address of the building: **Party Place Banquet** located at **B-2 Lawrence Road Inld Area, Delhi**
3. Type of Occupancy : Banquet, (Assembly) Ground Floor + Two UFs
4. Type of Case : Renewal
5. Details of previous NOC ; **F6/DFS/MS/2011/1091 Dated 03/06/2011**
6. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2011/649 Dated 11/04/2011
7. Date of inspection . 11-11-2016
8. Name of the Inspecting Officer : Udai vir Singh ADO (WP)
9. Name and designation of Officer
from the building side : Sh. Sunil Puri (Banquet Staff)
10. Year of Construction : 2004
11. Applicant's letter No. : Nil dated 18/10/2016

S N o	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Directive	Provided at site	Remarks MR/NM R
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	6 m	Provided ,560 cm	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	4 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	1x150cm, 1x170cm, 1x140cm, 1x160cm	MR(Being Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	2 Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2m	GF =2x240cm,2x120cm,1x133cm,2x100cm & 1x90cm FF =1x133cm,3x160cm,1x110cm, SF =1x160cm,1x240cm, & 1x116cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floor	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	14ABC, CO2 & WCO2	Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	3 Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternatd source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	3 Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements(All the pumps Provided at terrace)			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR

14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	50000 Ltrs +10,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. **F6/DFS/MS/2011/1091 Dated 03/06/2011** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- Sprinkler system has been removed due to leaking of the system as it is not required as per NBC.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation.

17/11/2016

ASD/WP/Udaipur High

17/11/16

17/11/16