

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/SZ/2016/ 1219

Dated: 28/11/16

FIRE SAFETY CERTIFICATE

Certified that the **Sant Nirankari Public School, Opp. Gali No-15, Govind Puri, New Delhi**, comprised of ground plus one upper floor was granted Fire Safety Certificate by this department for ground plus one upper floor vide letter No. F.6/DFS/MS/School/2014/SZ/356 Dated 13.03.2014. The premises was inspected by officer concerned of this department on 16.11.2016 in the presence of Mr. Vinod Vats, Teacher of the school and found that said school is now comprised of three interconnected blocks. **A Block: ground plus two upper floors, B & C Block: ground plus three upper floors.** The said school have deemed complied with the fire prevention and fire safety arrangements in accordance with circular no. 262-362 dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class **“Educational Building Group-B”** with effect from 28/11/ 2016 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/11/16 at New Delhi by


Vipin Kental
Chief Fire Officer
Ph.: 011-23412225

Copy to: -

1. The Principal, Sant Nirankari Public School,
Opp. Gali No-15, Govind Puri, New Delhi-110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Sant Nirankari Public School, Opp. Gali No.- 15 Govind Puri, New Delhi-110019		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	(Three interconnected blocks) Block A - Ground plus two upper floors, Block B - Ground plus three upper floors, Block C - Ground plus three upper floors		
4	Type of Case	Renewal / <i>Addition & Alteration, etc.</i>		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/356 Dated 13.03.2014 (FSC renewed for ground plus one upper floor)		
6	Fire Safety Directives Letter No	DOE Circular dated 17.01.2005 & 01.03.2011		
7	Date of Inspection	16.11.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Vinod Vats, Teacher		
10	Year of construction	1987, 2000, 2015		
11	Applicant letter No.	No. GNGES/DEL/02/09 dated 13.10.2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 Mts.	MR
	• Gate width	NA	4.5 Mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a) Number of Staircase			
	➤ Upper floors	Three	Four provided	MR
	➤ Basement floor	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	1.50m /0.75 m	Block A- 1.50 × 1 Block B- 1.50 × 2 Block C- 1.50 × 1	MR
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	Two	Four	MR
	e) Width of corridor	NA	NA	NA
	f) Door size	1 m	1 m	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	15 Nos.	18 Nos.	MR
	• Types	ABC/Co2	ABC- 15, Co2-03	MR
	• ISI Marking	ISI Marked	Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose reel	Ground to 2 nd floor- 03 Nos. Third floor- 02 Nos.	MR
	• Length of hose-reel hose.		30 mts	MR
	• Nozzle Diameter		05 mm	MR

Renewal

Sant Nirankari Public School, Govind Puri, New Delhi

h

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	NA	One	NA
	• Hose box.	NA	One	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	b) Terrace Level			
	➤ Discharge of pump.	Required	450 LPM × 3	MR
	➤ Head of pump.	40 mtr	40 mtr each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	NA	NA
	• Draw-off connection.	NA	NA	NA
	• Fire Service Inlet.	NA	NA	NA
	• Access to tank.	NA	NA	NA
	• Overhead tank capacity.	Required	15,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire Control Room.	• Detector System Panel.	NA	NA	NA
		• Flow Switch Panel.	NA	NA	NA
		• PA system Panel.	NA	NA	NA
		• Battery backup	NA	NA	NA
		• Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	One Co2 type fire extinguisher near electrical panel	NA	

The Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 17/01/2005 & 01.03.2011, Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2014/SZ/356 Dated 13.03.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

R.N. Singh
13/11

Signature of the Inspecting Officer

Name: R.N. Singh

Designation: ADO

Renewal

Sant Nirankari Public School, Govind Puri, New Delhi

Div. Officer (SD)

Amal
21/11/16

dy. (P.O.S.2)

amp
21/11



118/CF/S2
25/11/16.28/11

CF/S2

FT/10. W 24/11

M. S. K.