

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/Cinema/2016/WZ/1740

Dated: 02/12/16


FIRE SAFETY CERTIFICATE

Certified that the **Cinopolis (formerly known as Fun Cinemas)** located at TDI Mall, Moti Nagar, New Delhi – 110015 in a building comprised of 2 Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/MS/DFS/Cinema/2005/1962 dated 26-08-15, FSC to the Mall is issued vide letter no.F6/DFS/MS/2015/WZ/1445 Dated 11.08.2015. The premises was re-inspected by the officers concerned of this department on **23-11-2016** in the presence of **Sh. Mithun Sarkar (Manager Cinema)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 02/12/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/12/16 at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service


20/11

Copy to:

1. Sh. Mithun Sarkar (Manager Cinema)
Cinopolis (formerly known as Fun Cinemas) TDI Mall, Moti Nagar, New Delhi – 110015
2. Sh. Ravindra Singh SDM (HQ-I/DDMA)
GNCT of Delhi, Old Middle School Complex, Rampura, Delhi – 110035

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building : **Cinopolis (formerly known as Fun Cinemas)** located at TDI Mall, Moti Nagar, New Delhi – 110015.
2. Type of Occupancy : Assembly (2 Basement + Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/Cinema/2005/1962 dated 26-08-15
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2002/1040 dated 02-07-02 & F6/DFS/Cinema/2004/BP/370 dated 16-02-04
6. Date of inspection : 23-11-2016
7. Name of the Inspecting Officer : Mukesh Verma DO (MN)
8. Name and designation of Officer
from the building side : Sh. Mithun Sarkar (Cinema Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : 77/DDMA/(W)/LCT/FUN(M.N.)/201505 dated 28/10/16

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	20 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	05 nos.	05 no. Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 x 2 mtr 3 x 1.5 mtr	1x 136 cm, 1x 186 cm 1x 186 cm, 1x 192 cm 1x 141 cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits	Required	Provided	MR
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Old Case	Old Case	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation	Common with Mall		
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Found Sealed	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Found Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System	Common with Mall		
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	03 nos. each Audi	03 nos each Audi Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First Aid Hose Reels			

2/11/16

	floor	02 no. in each Area	02 no. in each Area	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required at Mall	Provided	M.R
	• Upper Floor	Required at Cinema	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants Common with Mall			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants Common with Mall			
	• Total number of hydrants	required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements Common with Mall			
	• Ground Level			
	• Discharge of main pump	2850 lpm	Provided	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace-level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR
	➤ Power supply	NR	NR	NR
	➤ Auto starting of pump	NR	NR	NR
14.	Captive water Storage for fire fighting Common with Mall			
	• Under ground tank capacity	1,50,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR

2/25/21

18.	Refuge Area			
	➤ Total area	Required	Provided	MR
	➤ Location	Open Terrace	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO ₂ Flooding System for HT & LT Panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/MS/DFS/Cinema /2005/1962 dated 26-08-15** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Mukesh Verma
 Designation DO (West)

Mukesh Verma 25/11/16
 Dy. CPO (W2) - on leave
 CPO (West) *[Signature]* 28/11/16

FT P/S

DO/W F.T./F.S.C. is put up for signature please.

[Signature] 30/11/16

CPO (West) *[Signature]*
 1/12/16