

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2016/ 1734

Dated: 01/12/2016

FIRE SAFETY CERTIFICATE

Certified that the Vishal Bharti Public School at A-1 Block, Paschim Vihar, New Delhi - 110063, comprised of Ground + Two upper floors only owned / occupied by Modern Delhi Citizen Educational Society (Regd.), has already been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2013/WZ/918 date 16.09.2013. The premises was re-inspected by the officer concerned of Fire Service on 22.11.2016 in presence of Smt. Amita Saxena (Vice-Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of circular issued by Director of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005 and that the building / premise is fit for occupancy class Educational (Group-B) with effect from 01 / 12 /2016 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 01/12/2016 **at New Delhi by.**


01/12/16

(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Smt. Amita Saxena (Vice-Principal), Vishal Bharti Public School, A-1 Block, Paschim Vihar, New Delhi -110063.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Vishal Bharti Public School
A-1 Block, Paschim Vihar, N.Delhi-63.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2013/WZ/918 dt. 16.09.2013
5. Fire Safety directives Letter No. : D.O.E. circular dated 17.01.2005
6. Date of inspection : 22.11.2016
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
from the building side : Smt. Amita Saxena (Vice-Principal)
9. Year of Construction : 1989
10. Applicant's letter No. : VBPS/AO/2016 dated 07.10.2016

Ground + Two Floors

Plot Area = 1.5 Acres

Covered Area=941 M²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE <u>Cir.17.1.2005</u> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	2.14 mtr x 1 2.10 mtr x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NR	NR	NR
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR

N/17

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NR	NR
	• Upper floors	12 a/c per hour	NR	NR
5.	Fire Extinguishers			
	• Total numbers	12	21	MR
	• Types	ABC/Co2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	6.5 MM	6.5 MM	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

2/18

11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level	NR		
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	220 Lpm.	450 LPM 180 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	25,000 ltr	MR
	➤ Draw of connection	NR	Provided	MR
	➤ Fire service inlet	NR	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	2500 Ltr.	5,000 ltr	MR

[Handwritten signature]


		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-A) General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F.6/DFS/MS/School/2013/WZ/918 dt. 16.09.2013** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

