

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001


No. F6/DFS/MS/2016/W2/1773

Dated: 08/12/16

FIRE SAFETY CERTIFICATE

Certified that the **M/s Platinum Banquet** a unit of **Care Food & Hospitalities** Located at **71/4, Ground Floor, Shivaji Marg Najafgarh Road, New Delhi-110015** in a building comprised of Ground + Mezzanine Floors owned/ occupied by **M/s Platinum Banquet** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23-11-2016 in the presence of Mr. Sukhvinder Pal Singh (Owner) and found that the said building / premises is fit for occupancy class "Assembly" Group D for **GROUND FLOOR ONLY** with effect from 08/12/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .. 08.12.16..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service..

Copy to:

1. Sh Sukhvinder Pal Singh, M/s Platinum Banquet a unit of Care Food & Hospitalities 71/4, Ground Floor, Shivaji Marg Najafgarh Road, New Delhi-110015
2. Dy. Health Officer, Karol Bagh Zone,
NDMC, Public Health Department, Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Mezzanine floor shall be kept closed and not be used for any purpose.
7. Basement if any shall be used strictly as per Building Bye Laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The FSC is for Ground Floor Only.

INSPECTION REPORT

1. Name & address of the building: M/s Platinum Banquet a unit of Care Food & Hospitalities 71/4, Ground Floor, Shivaji Marg Najafgarh Road, New Delhi-110015
2. Type of Occupancy : Assembly (At Ground Floor in a building comprised of Ground + Mez. Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 23/11/2016
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Sukhvinder Pal Singh (Owner)
9. Year of Construction :
10. Applicant's letter No. : DHO/KBZ/2016/1504 dated 01-10-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	12 Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	Provided	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	1x165cm &1x170cm	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	NR	NR	NR
	e. Width Of Corridor			
	f. Door Size	NA	NA	NA
		2X2m,	1x210cm, 1x2m	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Inside	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Inside	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Inside	Provided	MR
8.	MOEFA	Required	Found functional	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA


13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	900 lpm Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		10, 000 litres	15,000 litres Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA


20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--------------------------------------------------------------------------	----	----	----

* The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010/issue shortcomings as noted at serial numbers

..... Nil

Signature of the Inspecting Officer
 Officer 
 Name Uday Kumar Singh
 Designation ADO/WP

Signature of the Inspecting 
 Name Sh. Mukesh Verma
 Designation DO/W

~~Dr. CFO (WZ) on leave.~~
~~CFO (West)~~
 28/11/16

FIPs