

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No.: F6/MS/DFS/EH/ 2016/MD2/1782

Dated:- 15/12/16

FIRE SAFETY CERTIFICATE

Certified that the Pizza Hut located at Shop No. 12 (GF), Aggarwal Fun City Mall, CBD Shahdara, owned/occupied by Haldiram Ethnic Foods Pvt. Ltd., was granted FSC vide letter no. F6/DFS/MS/EH/2012/4283 Dated 16/11/2012. The premises was re-inspected by officer concerned of this department on 07/12/2016 in the presence of **Sh. R.K.Yadav** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with N.B.C. Part IV and is fit for occupancy **Group - D, 'Assembly Building'** with effect from 15/12/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to, compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on15/12/16.....at New Delhi by.

W
14/12/16
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer,
East Delhi Municipal Corporation,
Health Department, Karkardooma
South Zone, Shahdara, Delhi
2. M/s Devyani International Limited,
F-2/7, Okhla Industrial Area Phase – I,
New Delhi - 110020

o/c

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. All comments/ directions of the Licensing Department shall always be permitted and followed.
5. Basements shall be used as per BBL.
6. Any deviation, with regards to construction deviation, ventilation, occupancy, structural stability, electric installation etc. may be got verified from the concerned authorities.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.

INSPECTION REPORT

1. Name & address of the building : Pizza Hut at Shop No. 12 (GF), Aggarwal Fun City Mall, CBD Shahdara, Delhi.
2. Type of Occupancy : Eating House (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC/FSC : F6/DFS/MS/EH/2012/2185 dated 19/06/2012
5. Fire Safety directives letter No : NBC Part - IV
6. Date of inspection : 07/12/2016
7. Name of the Inspecting Officers : DO S K Dua
8. Name and designation of officers
from the building side : Sh. R.B.Yadav
9. Year of Construction : 2005
10. Applicant's letter No. : NIL dated 25/11/2016

FSC issued to Aggarwal fun city mall vide letter No. - F-6/DFS/MS/2015/ND2/1626 dated 08/09/15

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs.	26 Mtrs.	MR
	• Gate width	4.5 Mtrs.	5.0 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2.5 Mtrs.	2.5 Mtrs.	MR
	h. Door Size	2.0 Mtrs.	2 nos.(1.0 Mtrs. & 2.0 Mtrs.)	MR (old case)
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Types IS marking 	ABC & Co2 ISI marked	ABC & Co2 Provided	MR MR
6	First-Aid Hose Reels. - Common with Mall			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 No. 30 m 05 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system. - Common with Mall			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Heat & Smoke Control Room Security Room Battery & DG Set Different Locations	Provided 1 st Basement Provided Provided Provided	MR MR MR MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System. - Common with Mall			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A Required Required	N/A Provided Provided	N/A MR MR
11	Internal Hydrants - Common with Mall			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 01 Nos. 02 Nos.	100 mm Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	01 Nos. 01 Nos.	MR MR
13	Pumping Arrangements. - Common with Mall			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head 	Required 2280 LPM 60 Mtrs. 1 nos. 450 LPM 60 Mtrs. 2280 LPM 60 Mtrs. Required Required N/A N/A N/A N/A N/A N/A N/A N/A	Provided Provided 60 Mtrs. Provided Provided 60 Mtrs. Provided 60 Mtrs. Provided Provided N/A N/A N/A N/A N/A N/A N/A	MR MR MR MR MR MR MR MR MR MR N/A N/A N/A N/A N/A N/A N/A

- 13/13 -

	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.	<i>- Common with Mall</i>		
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2012/2185 dated 19/06/2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

S K Dua
Signature of the Inspecting Officer

Name : S K Dua

Designation : DO (ED)

DeFO (MS/2)
9/12

M-s cell

Verified 13/12/16.