

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DF3/MS/2015/2405

Dated: 27.11.2015

FIRE SAFETY CERTIFICATE

Certified that the Dalit Prahri at Khasra No.234, Mulla Colony, Village Gharoli, Delhi-96, comprised of ground floor only owned/occupied by Dalit Prahri have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 25.08.2015 & 23.09.2015 in the presence of Sh.Vikash Singh (Manager) and that the building is fit for occupancy Group G-1(Industrial Building), with effect from 27.11.2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 27.11.2015 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

o/c RS

To,

Mr.Vikash Singh (Manager)
Dalit Prahri, Khasra No. 234, Mulla Colony,
Village Gharoli, Delhi-96

Conditions

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six Months prior to its expiry.

1. Name & address of the building : Dalit Prahri, Khasra No. 234, Mulla Colony,
Village Gharoli, Delhi-96,
2. Building is comprised of : Ground floor
3. Type of Occupancy : Industrial (Mid Day Meal Kitchen)
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 25.08.2015 & 23.09.2015
8. Name of the Inspecting Officers: : R.K. Yadav (ADO)
9. Name of the designation of Officer
from the building side : Mr. Vikas Singh (Manager)
10. Year of Construction : 2007
11. Applicant's letter No : DP/1375/2015-16 dated 13.07.2015


S.No	Minimum Standards on fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	N.A	N.A	N.A
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	N.A	N.A	N.A
	Basement	N.A	N.A	N.A
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	N.A	N.A	N.A
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	1.25	1.5	MR
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A

5.	Fire Extinguisher	6 no.	14 no.	MR
	Total numbers	CO ₂ & ABC	CO ₂ & ABC	MR
	types	ISI marked	ISI marked	MR
	IS marking			
6	First-aid-Hose Reels.	01 no.	01 no.	MR
	Total numbers of each floor	30 mtrs.	Provided	MR
	Length of hose reel hose	05 mm	Provided	MR
	Nozzle diameter			
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	N.A	N.A	N.A
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	Ground Level	N.A	N.A	N.A
	Discharge of main Pump	N.A	N.A	N.A
	Head of Main Pump	N.A	N.A	N.A
	Number of main pumps	N.A	N.A	N.A
	Jockey pump out put	N.A	N.A	N.A
	Jockey pump head	N.A	N.A	N.A
	Standby pump out put	N.A	N.A	N.A
	Standby pump Head	N.A	N.A	N.A
	Auto Starting /Manual stopping	N.A	N.A	N.A
	Pump House Access	N.A	N.A	N.A
	Terrace Level	N.A	N.A	N.A
	Discharge of pump	450 Lpm.	Provided	MR
	Head of the Pump	40 M	Provided	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemer's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Delhi Fire Service Act 2007 and Rules 2010, it is recommended to grant Fire Safety Certificate.



Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- A.D.O

DO/ED)

Submitted for approval please.