

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333

NO.F6/DFS/MS/Ind./2015/ 52/2118

Dated: 01/12/15

**FIRE SAFETY CERTIFICATE**

Certified that **Premises No. H9/B1, MCIE, Mathura Road, New Delhi** comprised of basement, ground, Mezzanine and first floor was granted NOC by this department vide letter No. F.6/DFS/MS/Ind./2013/361 dated 23.01.2013. The premises was re-inspected by the officer concerned of this department on 16-11-2015 in presence of Mr. Dalbir Singh, Manager and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class Commercial with effect from 01/12/15 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 01/12/15 at New Delhi by.

  
(Dr. G.C. MISRA)  
CHIEF FIRE OFFICER

Copy to: -

1. Mr. Gurbir Singh Madan, Plot No. H9/B1, MCIE, Mathura Road, New Delhi.
2. The Executive Engineer (Bldg.)-I, SDMC, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : Plot No. H-9/B-1, M.C.I.E., Mathura Road, New Delhi -44
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/Ind./2013/361 dated 23.01.2013
5. Fire Safety directives letter No : F6/DFS/MS/BP/86/1159 dated 14.08.1986
6. Date of inspection : 16-11-2015
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. Dalbir Singh, Manager
9. Year of Construction : 1987-88
10. Applicant's letter No. : nil dated 01.09.2015.

Building is comprised of Basement, ground, Mezzanine and first floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.20 mts	1.25 mts, 1.10 mts	MR being old case
	• Basements	1.20 mts	1.25 mts, 1.10 mts	MR being old case
	c. Protection of exits	---	---	---
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A



	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	Exhaust fan provided	MR
		12 a/c per hour	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	25 ABC, CO <sub>2</sub> ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	Provided	----
		N/A	Provided at GF	----
		N/A	N/A	N/A
		N/A	Provided	-----
		N/A	Provided	-----
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	Provided (100 mm)	----
		N/A	Provided	-----
		N/A	Provided	-----
12	<b>Yard Hydrants.</b>			

4/10

	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	Provided (02)	----
		N/A	Provided (02)	----
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	Provided(1620 LPM)	---
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	Provided 56 mts)	----
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	Provided(01)	----
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	180 LPM	Provided (180 LPM)	----
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	Provided 56 mts)	----
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	Provided(1620 LPM)	---
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	Provided 56 mts)	----
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	Provided	----
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	---	---	---
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	36 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>			
14	<b>Captive Water Storage for fire fighting. Maintained by mail</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	1,00,000 lts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10,000 liters	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR



18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	Provided	----
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/Ind./2013/361 dated 23.01.2013, renewal under the Delhi Fire Service Act-2007 & Delhi Fire Service Rules-2010 is recommended.

DFA is put up for approval & signature please

*DD/Secy online*  
*DCPO (S2) 24/11/15*

*M.K. Chattopadhyay*  
 24/11/15  
 Signature of the Inspecting Officer  
 Name M.K.CHATTOPADHYAY  
 Designation: - Asstt. Div. Officer (M.Rd)