

No. F.6/DFS/MS/EH/2015/SZ/ 2112

Dated: 30/11/15

FIRE SAFETY CERTIFICATE

Certified that The Village Restaurant (K.I.C. Food Products Pvt. Ltd) at Village Complex, Asian Games Village, Sirifort Road, New Delhi, running at ground floor & 1st floor of the building comprised of basement, ground plus one upper floor was granted NOC by this department vide letter No. F6/MS/DFS/EH/2012/4292 dated. 16.11.2012. The premises was re-inspected by the officers concerned of Delhi Fire Service on 18.11.2015 in the presence of Sh. Ajay Pundir (Manager) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 30/11/15 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 30/11/15 at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
T.No.011-2341433

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Authorized Signatory, M/s The Village Restaurant (K.I.C. Food Products Pvt. Ltd) at Village Complex, Asian Games Village, Sirifort Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N/13

INSPECTION REPORT

1	Name & address of the building	The Village Restaurant (K.I.C. Food Products Pvt. Ltd), at Village Complex, Asian Games Village, Sirifort Road, New Delhi		
2	Building Comprised of	B+G+1st floor. (Resturant running at ground & 1st floor)		
3	Type of Occupancy	Assembly building "D" Restaurant		
4	Type of case	Renewal		
5	Details of previous NOC	F6/MS/DFS/EH/2012/4292 dated. 16.11.2012		
6	Fire safety directives letter No	Nil		
7	Date of inspection	18.11.2015		
8	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO Vedpal (SJ)		
9	Name and designation of officers from the building side	Sh. Ajay Pundir (Manager),		
10	Year of construction	1982		
11	Applicant's letter No.	Nil dated 26.10.2015		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1 Access to building				
	1) Road width	Required	6 Mtr	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2 Number, width Type & arrangement of exits

a. Number of staircases				
	1. Upper floors	Two	Provided	MR
	2. basements	One	Provided	MR
b. Width of staircase				
	1. Upper floors	Required Old Case	1.25 & 1.00 Mtr	MR (Old Case)
	2. basements	Required Old Case	1 Mtr	MR (Old Case)
c. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required Old Case	Gr. Floor- 2.00 & 1.43 Mtrs & 1st floor- 1.5 & 1.64 Mtr Provided	MR

3 Compartmentation.

	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4 Smoke Management system.

	basement	30 a/c per hour 12 a/c per hour	Exhust Fans	MR
	upper floors		Exhust Fans	MR

5 Fire Extinguishers

	total numbers		18 Nos	MR
	Types		ABC, Co2 Provided	MR
	ISI marking	ISI	Yes	MR

		Required	Gr. Floor 2 Nos. & 1st floor- 1no. Provided	MR
	total numbers on each floor			
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5 MM	Provided	MR
7	Automatic fire detection and alarming system:-			
	Type of detectors	Required	Provided	MR
	location of Main Panel	Ground floor	Provided	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	Required	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	One	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 220 LPM	Provided	MR
	b. head of the pump	35 Mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			

N/07

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: No.			


The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/MS/DFS/EH/2012/4292 dated. 16.11.2012** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.



Signature of the inspecting officer
Name D. P. Bhardwaj
Designation : Divisional Officer (South)



Signature of the inspecting officer
Name Vedpal
Designation : ADO (SJ)