

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI


No.F6/DFS/MS/School/2015/ *N02/2135*

Dated: *04/12/15*

**FIRE SAFETY CERTIFICATE**

Certified that the (1)Rukmani Devi Jaipuria Public School (2) Seth Beni Pershad Jaipuria Prep. School (3) Beni Pershad Jaipuria Girls Sr. Sec.School located at 23-25,Rajpur Road,Delhi-110054 comprised of Basement,Ground + 3 Upper Floors was granted FSC by this department vide letter No.F6/DFS/MS/School/2012/4186 dated 08/11/12. The premises was re-inspected by the officer concerned of this department on 24/11/15 in the presence of Mr. S.K. Saxena (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and the premises / building is fit for occupancy, class B "Educational Building" with effect from *04/12/15*.....for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *04/12/15*.....at New Delhi.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph. 011-23414333

Copy to:- (1)Rukmani Devi Jaipuria Public School (2) Seth Beni Pershad Jaipuria Prep. School (3) Beni Pershad Jaipuria Girls Sr. Sec.School  
23-25,Rajpur Road,Delhi-110054.

(2) Director of Education,  
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate.

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

-N/10-

**INSPECTION REPORT**

- 1. Name & address of the building: - (1)Rukmani Devi Jaipuria Public School  
(2) Seth Beni Pershad Jaipuria Prep. School  
(3) Beni Pershad Jaipuria Girls Sr. Sec. School,23-25,Rajpur Road,Delhi-110054.
- 2. Type of occupancy:- Group – B Education Building  
Basement,Ground + 3 upper floor.
- 3. Type of case:- Renewal
- 4. Details of previous FSC:- No.F6/DFS/MS/School/2012/4186 dated 08/11/12.
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 24/11/15
- 7. Name of the inspecting officer:- D.O. Gurmukh Singh
- 8. Name & designation of officer:-  
From the building side:- Mr. S.K. Saxena (Principal).
- 9. Year of construction:- 2000
- 10. Applicant's letter No:- Nil. Dated 26/10/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Circular	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	24 mtr.	MR
	2) Gate width	5 mtr.	5 mtr.	MR
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	5 no.	5 no.	MR
	2. Basements	5 no.	5 no.	MR
	<b>B. Width of staircase</b>			
	1. Upper floors	1.50 mtr.	1.70 mtr. X 4 & 1.10 mtr. (iron)	MR
	2. Basements	1.50 mtr.	1.70 mtr. X 4 & 1.10 mtr. (iron)	MR
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A

h



-N/11-

	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	66 Nos.	66 Nos.	MR
	2) Types	ABC & co2	ABC & co2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number at each floor	04 No.	04 No.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr	MR
	3) Nozzle diameter	5 mm.	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	04 No.	04 No.	MR
	3) Hose box	04 No.	04 No.	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			

h



N/12

	a) Discharge of pump	900 LPM & 450 LPM	900 LPM X2 & 450 LPM X2	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	20,000 ltrs.	20,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	50,000 ltrs.	50,000 ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:- 4 sand buckets provided.</b>			MR

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/School/2012/4186 dated 08/11/12, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

*bschnd*  
Gurmukh Singh  
Divisional Officer

