

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. FG/DFS/MS/BNOR/2015/WZ/2143

Dated: 08/12/15

FIRE SAFETY CERTIFICATE

Certified that the M/s Mehak Banquet (A Unit of Amour Banquets Pvt. Ltd.) Upper Ground Floor and First Floor only located at Plot No. 43/35, Rohtak Road, West Punjabi Bagh, New Delhi - 110026 in a building comprised of Basement + Stilt + Upper Ground + 3 Upper Floors owned/ occupied by M/s Mehak Banquet (A Unit of Amour Banquets Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 05-11-2015 in the presence of Mr. Rohit Kochar (Director) and found that the said building / premises is fit for occupancy class " Assembly" Group D with effect from 08/12/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on08/12/15... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. Sh. Rohit Kochar (Director),
M/s Mehak Banquets (A unit of Amour Banquets Pvt. Ltd.),
43/35, Rohtak road, West Punjabi Bagh, New Delhi - 26.
2. Dy. Health Officer, West Zone,
South Delhi Municipal Corporation,
Vishal Enclave, Rajouri Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Mehak Banquet, Upper Ground Floor & First Floor, 43, Road No. 35, Rohtak Road, West Punjabi Bagh, New Delhi – 110026.
2. Type of Occupancy : Assembly (Basement + Stilt + Upper Ground + 3 Upper Floors) Height = 14.75m.
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 05-11-2015
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Rohit Kochar (Owner)
9. Year of Construction : 2014
10. Applicant's letter No. : D-2131/HD/WZ Dated 15-10-2015

Area=464.503 sqm.
Basement=Storage,
Stilt=Parking
UGF & FF = Banquet Hall
Second Floor = Vacant
Third Floor = Rooms

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1X2m, 1X1.5m	1X205cm, 1X1m, 1X1.5 m	MR
	• Basements	NA	150 cm, 156 cm	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	2 Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m	UGF (3 exits) – 205 cm, 200 cm, 168 cm, FF (2 exits) – 200 cm, 200 cm	MR

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	Provided	MR
	• Sprinkler above false ceiling	NR	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	2280 lpm Provided	MR
	➤ Head of main pump	NR	70 m Provided	MR
	➤ Number of main pumps	NR	1 Provided	MR
	➤ Jockey pump out put	NR	180 lpm Provided	MR

	➤ Jockey pump head	NR	70 m Provided	MR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR ✓
	➤ Head of the pump	40 m	Provided	MR ✓
	➤ Power supply	Required	Provided	MR ✓
	➤ Auto starting of pump	Required	Provided	MR ✓
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	54,000 litres	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 litres	Provided	MR ✓
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR (as lift is terminating at stilt floor)
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	NR	Provided	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Note: The premises was earlier mentioned as Basement + Stilt + Ground + Three Upper Floors now, FSC is now requested for Upper Ground Floor and First Floor as per DHO letter no. D-2131/HD/WZ dated 15-10-15. The ground floor is now upper ground floor. The height upto First Floor is 8.5 m. The rear spiral staircase as shown in the plan is now 1m wide normal staircase. The lift is now terminating at Stilt Floor. ✓

Signature of the Inspecting Officer
Name
Designation

Mukesh Verma
24/10/15
Mukesh Verma
ADO (MN)

Signature of the Inspecting Officer
Name
Designation