

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2015/2185

Dated: 15/12/2015

FIRE SAFETY CERTIFICATE

Certified that the Punjabi Bagh Club located at Punjabi Bagh, Ring Road, New Delhi-110026 comprised of Basement + Ground + 2 Upper Floors was granted NOC by this department vide letter no. F6/DFS/MS/Club/2012/253 dated 27-01-2012. The premises was re inspected by the officers concerned of this department on 03-12-2015 in the presence of Mr. Madhup Wadhwa (General Manager) of the Club and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010. Hence the NOC is renewed and premises is fit for Class D (Assembly) occupancy with effect from 15/12/2015 for a period of three years subject to conditions printed below.

Issued on 15/12/2015 at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service  
Tel. -011-23414250

Copy to:

1. Sh. Gurinder Pal Singh (Raju), Hony. Gen. Sec.  
Punjabi Bagh Club,  
Punjabi Bagh, Ring Road, New Delhi-110026.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: **Punjabi Bagh Club** located at **Punjabi Bagh, Ring Road, New Delhi-110026.**
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter no. F6/DFS/MS/Club/2012/253 Dated 27-01-2012.
5. Fire Safety directives Letter No. : Letter no. F6/DFS/MS/2006/347 dated 08-02-2006
6. Date of inspection : 03-12-2015
7. Name of the Inspecting Officer : Do West & ADO (MN)
8. Name and designation of Officer  
from the building side : Mr. Madhup Wadhwa (General Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil dated 14-11-2015

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirement     | Provided at site | Remarks MR/NMR |
|------|---|---------------------|------------------|----------------|
| 1.   | Access of building  |                     |                  |                |
|      | • Road width  | 9 mtrs              | Provided         | MR             |
|      | • Gate width  | 5 mtr               | Provided         | MR             |
|      | • Width of internal road                                    | NA                  | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |                     |                  |                |
|      | a. Number of staircases                                     |                     |                  |                |
|      | • Upper floors  | 2                   | Provided         | MR             |
|      | • Basements   | 2                   | Provided         | MR             |
|      | b. Width of staircases                                      |                     |                  |                |
|      | • Upper floors  | Old Case            | Old Case         | MR             |
|      | • Basements   | Old Case            | Old Case         | MR             |
|      | c. Protection of exits                                      |                     |                  |                |
|      | • Fire check door   | Required            | Provided         | MR             |
|      | • Pressurization  | NA                  | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | 2                   | Provided         | MR             |
|      | e. Width Of Corridor  | NA                  | NA               | NA             |
|      | f. Door Size  | Old Case            | Old Case         | MR             |
| 3.   | Compartmentation  |                     |                  |                |
|      | • Fire check door   | Required            | Provided         | MR             |
|      | • Sealing of electrical shafts                              | NA                  | NA               | NA             |
|      | • Fire Rating of shaft door                                 | NA                  | NA               | NA             |
|      | • Water Curtain   | NA                  | NA               | NA             |
|      | • Fire Dampers  | NA                  | NA               | NA             |
| 4.   | Smoke managements System                                    |                     |                  |                |
|      | • Basements   | Required            | Provided         | MR             |
|      | • Upper floors  | Natural ventilation | Provided         | MR             |



|     |  |  |                      |    |
|-----|--|--|----------------------|----|
| 5.  | Fire Extinguishers   |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>   | 20 nos.<br>ABC & CO <sub>2</sub><br>ISI marked | Provided             | MR |
|     |  |  | Provided             | MR |
|     |  |  | Provided             | MR |
| 6.  | First – Aid Hose Reels   |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>   | 2  | Provided             | MR |
|     |  | 30m  | Provided             | MR |
|     |  | 5mm  | Provided             | MR |
| 7.  | Automatic fire detection and alarming system   |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>  | Heat & smoke                                   | Provided             | MR |
|     |  | Ground floor                                   | Provided             | MR |
|     |  | Ground floor                                   | Provided             | MR |
|     |  | Required                                       | 400 KVA              | MR |
|     |  | Required                                       | Provided             | MR |
| 8.  | MOEFA  | Required                                       | Provided             | MR |
| 9.  | Public Address System  | Required                                       | Provided             | MR |
| 10. | Automatic Sprinkler System   |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>  | Required                                       | Provided             | MR |
|     |  | NA   | NA                   | NA |
|     |  | NA   | NA                   | NA |
| 11. | Internal Hydrants:   |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>  | 150 mm   | Provided             | MR |
|     |  | 2  | Provided             | MR |
|     |  | 2  | Provided             | MR |
| 12. | Yard Hydrants  |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>   | 6  | Provided             | MR |
|     |  | 6  | Provided             | MR |
| 13. | Pumping Arrangements:  |  |                      |    |
|     | <ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> </ul>   | NA   | 1620 lpm<br>Provided | MR |
|     | <ul style="list-style-type: none"> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> </ul> | NA   | 40 mtr               | MR |
|     |  | 1  | Provided             | MR |
|     |  | 180 LPM  | Provided             | MR |
|     |  | 40 mtr   | Provided             | MR |
|     |  | NA   | NA                   | NA |
|     |  | NA   | NA                   | NA |
|     |  | Required                                       | Provided             | MR |
|     |  | Required                                       | Provided             | MR |
|     | <ul style="list-style-type: none"> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> </ul>   | 900 LPM  | Provided             | MR |
|     |  | 40Mtr  | Provided             | MR |
|     |  | Required                                       | Provided             | MR |

|     |  |               |                        |     |
|-----|--|---------------|------------------------|-----|
|     | ➤ Auto starting of pump  | Required      | Provided               | MR  |
| 14. | Captive water Storage for fire fighting:                                 |               |                        |     |
|     | • Under ground tank capacity   | NA            | Provided<br>50,000 ltr | MR  |
|     | ➤ Draw off connection  | NA            | Provided               | MR  |
|     | ➤ Fire service inlet   | Required      | Provided               | MR  |
|     | ➤ Access to tank   | Required      | Provided               | MR  |
|     | • Overhead Tank capacity   | 10,000 litres | Provided               | MR  |
| 15  | Exit Signage   | Required      | Not Provided           | NMR |
| 16. | Provision of Lifts   |               |                        |     |
|     | ➤ Pressurization of Lift Shaft   | NA            | NA                     | NA  |
|     | ➤ Pressurization of lift lobby   | NA            | NA                     | NA  |
|     | ➤ Communication in lift Car  | NA            | NA                     | NA  |
|     | ➤ Fireman's Grounding Switch   | NA            | NA                     | NA  |
|     | ➤ Lift Signage   | NA            | NA                     | NA  |
| 17. | Standby power supply   | Required      | Provided               | MR  |
| 18. | Refuge Area  |               |                        |     |
|     | ➤ Total area   | NA            | NA                     | NA  |
|     | ➤ Location   | NA            | NA                     | NA  |
| 19. | Fire control room  |               |                        |     |
|     | ➤ Detector system panel  | Required      | Provided               | MR  |
|     | ➤ Flow Switch Panel  | Required      | Provided               | MR  |
|     | ➤ PA System Panel  | Required      | Provided               | MR  |
|     | ➤ Battery backup   | Required      | Provided               | MR  |
|     | ➤ Building Floor Plans   | Required      | Provided               | MR  |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA            | NA                     | NA  |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Club/2012/253 Dated 27-01-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*Mukesh Verma*  
4/12/15  
Mukesh Verma  
ASO (MR)