

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/MS/DFS/School/2015/52/2601

Dated: 26/11/15

FIRE SAFETY CERTIFICATE

Certified that Aadyant School (Manohar Memorial Educational Society), located at Plot No-10-11, Nelson Mandela Road, Near Gurudwara, Vasant Kunj, New Delhi-110070.comprised of basement ,ground & two upper floors owned/occupied by Manohar Memorial Educational Society was granted FSC by this department vide letter no. F6/DFS/MS/School/2012/3402 dated 18/09/2012. The school building was re-inspected by the officer concerned of this department on 18/11/2015 in the presence of Mr. Yoginder Kumar and found that the School have deemed complied with the fire prevention and fire safety requirements and that the school building is fit for occupancy class Group "B" "Educational"(School) with effect from the date of issue. 26/11/15 of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 26/11/15 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

7c
26/11/15

Copy to: -

- 1) The Princippal,
Aadyant School,
Plot No-10-11,Nelson Mandela Road,Near Gurudwara,
Vasant Kunj, New Delhi-110070.
- 2) Director of Education, Old Secretariat, Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

211

INSPECTION REPORT

1. Name & address of the building:- Aadyant School(Manohar Memorial Educationl Society), Plot No-10-11,Nelson Mandela Road,Near Gurudwara, Vasant Kunj, New Delhi-110070.
2. Type of occupancy:- Educational (School)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/School/2012/3402 dated 18/09/2012
5. Fire safety directives No.- Nil
6. Date of inspection:- 18/11/2015
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Yogender Kumar
9. Year of construction:- 2004
10. Applicant's letter No:- Nil dated 16/09/2015.
11. Composition of building :- Sankeen basement, ground + 2 upper Floor

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	12 Provided	MR
	2) Gate width	Required	5.54 mtr	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02nos	Provided 03no	MR
	2. Basements	02nos	Provided 02no	MR
	B. Width of staircase			
	1. Upper floors	1.50m	Provided 1.50m,1.36m &1.27m	MR
	2. Basements	Required	Provided 1.50m & 1.36m	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 nos.	MR
	E. Width of corridor	Required	2.58 mtr	MR
	F. Door size	Required	1.16mtr	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	17 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR


N/12

6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Provided 1 Nos at each floor	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	1nos	Provided	MR
	3) Hose box	1nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided 450Lpm	MR
	b) Head of pump	35mtr	35 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	20,000ltrs	Provided	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR

✓

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No F6/DFS/MS/School/2012/3402 dated :- 18/09/2012, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.
Accordingly DFA is put up for perusal and signature pl.



Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- Assistant Divisional Officer (BCP)