

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. FG/DFS/MS/School/2015/w2/2217

Dated: 18/12/2015

**FIRE SAFETY CERTIFICATE**

Certified that Govt. Girls Sr. Sec. School, Pocket-2, Sector-A-6, Narela, Delhi -110040 comprised of Single Block, Ground + Three upper floors owned/occupied by Govt. Girls Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 29/10/2015 in the presence of Sh. Rajender Kumar Verma (Principal) and that the building / premises is fit for occupancy of Group Class B (Educational) building with effect from 18/12/2015 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/12/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250  


**Copy to:**

1. The Principal, Govt. Girls Sr. Sec. School, Pocket-2, Sector-A-6, Narela, Delhi -110040.
2. The Director of Education, Old Secretariat, Delhi

**INSPECTION REPORT**Single block  
Gr + Three upper floor only

1. Name & address of the building : Govt. Girls Sr. Sec. School, Pocket-2, Sector-A-6, Narela, Delhi-110040
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Letter No. Nil dated Nil
5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011 ✓
6. Date of inspection : 29/10/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers  
from the building side : Sh. Rajender Kumar Verma (Principal)
9. Year of Construction : 2002 & 2006 ✓
10. Applicant's letter No. : 15(B)/AE (E) PED EMSD M-3523/2015-16/597 dated 15/09/2015

**Plot Area:**7924.2 sq yard      **Covered Area:**4642.00 sq yard      **No. of Students:**1472      **NO. of Class Rooms:** 27 + 11 room for other purpose and 6 labs

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	Accessible	Accessible	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	1.50 mtr each	MR ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	1.50 mtr	2.00 mtr	MR
	h. Door Size	1.00 mtr	1.10 mtr each Double Door	MR ✓

3	<b>Compartmentation.</b>				
	• Fire check door	—	—	—	—
	• Sealing of electrical shafts	—	—	—	—
	• Fire Rating of shaft door	—	—	—	—
	• Water Curtain	—	—	—	—
	• Fire Dampers	—	—	—	—
4	<b>Smoke Management System.</b>				
	• Basements	30 a/c per hour	—	—	—
	• Upper floors	12 a/c per hour	—	—	—
5	<b>Fire Extinguishers</b>				
	• Total numbers	22 ABC/CO2	12	12	MR
	• Types	ISI marked	ABC	CO2	MR
	• IS marking		Yes		MR
6	<b>First-Aid Hose Reels.</b>				
	• Total numbers on each floor	Two	P		MR
	• Length of hose reel hose	30 m	P		MR
	• Nozzle diameter	5 mm	P		MR
7	<b>Automatic fire detection and alarming system.</b>				
	• Type of detectors	—	—	—	—
	• Location of Main Panel	—	—	—	—
	• Location of Repeater Panel	—	—	—	—
	• Alternate source of power	—	—	—	—
	• Hooters' Location	—	—	—	—
8	<b>MOEFA</b>	—	—	—	—
9	<b>Public Address System.</b>	—	—	—	—
10	<b>Automatic Sprinkler System.</b>				
	• Basement	—	—	—	—
	• Upper Floor	—	—	—	—
	• Sprinkler above false ceiling	—	—	—	—
11	<b>Internal Hydrants</b>				
	• Size of riser/down-comer	NR	P	—	—
	• Number of hydrants per floor	NR	P	—	—
	• Hose Box	NR	P	—	—

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	2 X 900 LPM	P	MR ✓
	➤ Head of the pump	40 m	P	MR ✓
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	50,000 ltr .	P	MR ✓
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 ltr	P	MR ✓
15	<b>Exit Signage.</b>	R	P	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	—	—	—

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		—	—	—

**Note:-**General requirements for school as per Director of Education Circular dated...03/01/2011

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories ...No.....
3. Electric wiring .....**Concealed**.....**MCB**...**Provided**.....  
Electric circuit.....**ELCB**... **Provided** .....
4. Electric meter board ..... **Not below S/C** .....
5. Basement use as per BBL 1983..... **N/A** .....
6. Emergency telephone no. board.....**Displayed**.....
7. Generator set.....**No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....Nil.....

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
*[Handwritten Designation]*

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
*[Handwritten Name]*  
*[Handwritten Designation]*

