

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/MS/DFS/Auditorium/2015/ 2173

Dated: 11/12/15

FIRE SAFETY CERTIFICATE

Certified that the Arya Auditorium(Formerly Lalit Suri Auditorium) of Arya Orphanage located at Des Raj Campus, C-Block, East Of Kailash, New Delhi, comprised of basement, ground & 01 upper floors was granted FSC by this department vide letter No.F6/DFS/MS/Auditorium/2012/100 dated: 11/01/2012. The premises was re-inspected by the officer concerned of this department on 03/12/2015 in the presence of Mr. Rahul Heer and observed that the Auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D, Assembly Building(Auditorium) with effect from-----11/12/15-----for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued -----11/12/15-----at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

9c 47

Copy to:-

- (1) The Jt. Commissioner of Police (Lic. Amst.)
Licensing, 1st Floor
P.S. Defence Colony, New Delhi
- (2) Mr.Nitinjya Chaudhry
Secretary, Arya Auditorium,
Arya Orphanage ,Des Raj Campus, C-Block,
East Of Kailash,New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL/NBC.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Arya Orphanage, Arya Auditorium (Formerly Lalit Suri Auditorium), Des Raj Campus, C-Block, East of Kailash, New Delhi-110065.

2. Type of occupancy:- Group-D Assembly Building (Auditorium)

3. Type of case: - Renewal.

4. Details of previous NOC: - F6/DFS/MS/ Auditorium/ 2012/100 dated 11/01/2012.

5. Fire safety directives No.- Nil

6. Date of inspection:- 03/12/2015

7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)

8. Name & designation of officer From the building side: - Mr. Rahul

9. Year of construction:- 1969 (renovated in 2008-2009)

10. Applicant's letter No:- 20751/Joint CP/Lic.(Amst.) dated 06/11/2015.

Building is comprised of Small Basement, Ground + 01 Upper Floor.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtrs.	Provided	MR
	2) Gate width	4.5 m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	Provided 02 nos.	MR
	2. Basements	Required	Provided 01 no.	MR
	B. Width of staircase			
	1. Upper floors	Required	1.72 & 1.55 mtrs	MR Old Case
	2. Basements	Required	1.10m	MR Old Case
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	02 nos.	MR
	E. Width of corridor			
	F. Door size	Required	3.12 m	MR
		GF-04 nos FF-02nos.	1.70,1.5,1.48,1.68 & 1.68 m 1.48 & 1.63 m	MR Old Case
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	24Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

2/17

6.	First-Aid Hose Reel			
	1) Total number of each floor	02 no.	Provided	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke & Beam type Provided	MR
	2) Location of main panel	First floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided DG Set, UPS	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150mm	Provided	MR
	2) Number of hydrants per floor	02	Provided	MR
	3) Hose box	02	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	05	Provided	MR
	2) Hose box	05	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2800 lpm	Provided	MR
	b) Head of main pump	60 m	Provided	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	180 lpm	Provided	MR
	e) Jockey pump head	60 m	Provided	MR
	f) Stand by pump output	2280 lpm	Provided	MR
	g) Stand by pump head	60 m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450LPM	Provided	MR
	b) Head of pump	30 m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltrs	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A


218

19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. The shortcoming issued by the department vide letter no F.6/DFS/MS/Auditorium/2015/2222 dated : 02/11/2015 have been rectified fully.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/ Auditorium/ 2012/100 dated 11/01/2012., renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pl.


 Signature of the inspecting officer
 Name: - D.B.Mukherjee.
 Designation:- Assistant Divisional Officer (BCP)

Do (Lover)

21/11/15