

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/EH/2015/021 2235

Dated: 23/12/15

**FIRE SAFETY CERTIFICATE**

Certified that the **McDonalds Family Restaurant** located at **23, West Punjabi Bagh, Central Market, New Delhi** was issued FSC vide Letter No. F6/DFS/MS/EH/2012/3710 dated 10-10-2012 at Basement + Ground + First Floor in a building comprised of Basement + Ground + 3 Upper Floors. The premises was re inspected by the officers concerned of this department on 11-12-2015 in the presence of Mr. Atul Kukreja and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy Class-D "Assembly" Group D with effect from 23/12/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....23/12/15..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer,  
Ph: 011-23414250.

Copy to:

1. Shailendra Pandey (Authorised Signatory),  
McDonalds Family Restaurant,  
23, West Punjabi Bagh Central Market, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building: McDonalds Family Restaurant Located at 23, West Punjabi Bagh, Central Market, New Delhi. Basement + Ground + First Floor in a Building comprised of Basement + Ground + 3 Upper Floor.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2012/3710 dated 10-10-2012.
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 10-12-2015
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer  
from the building side : Mr. Atul Kukreja
9. Year of Construction :
10. Applicant's letter No. : CPRPL/FM/OM/NOC/2015-16/230 dated 19-11-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	Old case	90 cm	M.R being old case
	• Basements	Old case	90 cm	M.R being old case
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	1.5approx	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10	12	MR
	• Types	DCP, CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	No false ceiling	NA	Not applicable
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	Not applicable
	➤ Head of main pump	NA	NA	Not applicable
	➤ Number of main pumps	NA	NA	Not applicable
	➤ Jockey pump out put	NA	NA	Not applicable
	➤ Jockey pump head	NA	NA	Not applicable
	➤ Standby Pump out put	NA	NA	Not applicable
	➤ Standby Pump Head	NA	NA	Not applicable
	➤ Auto Starting/Manual stopping	NA	NA	Not applicable
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	Old case	450 & 225 LPM	MR
	➤ Head of the pump	45 mtr	-Provided	MR
	➤ Power supply	Required	-	MR
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			

	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/3710 dated 10-10-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
*Mukesh Verma* 14/12/15

Name *Mukesh Verma*

Designation *ADO (MN)*

Signature of the Inspecting Officer

Name

Designation

*DO (West)*  
*15/12*

*554/DC/20 (MN)*