

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


NO. F6/DFS/MS/EH/2015/52/2221

Dated: 21/12/15

FIRE SAFETY CERTIFICATE

Certified that M/S Public Affair Restaurant (A Unit of RVN Hospitality) located at Flat No.67 & 68(1st & 2nd floors), Khan Market, New Delhi-110003, comprised of ground plus two upper floors (Restaurant at 1st and 2nd floor only), owned/occupied by RVN Hospitality, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on dated 10.10.2015 in the presence of Sh. Navneet Kalra, Partner and that the building is fit for occupancy class "Eating House" with effect from ..21/12/15.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on.....21/12/15..... at New Delhi by


Dr. G.C. Misra
Chief Fire Officer
Delhi Fire Service
Tele. No. - 23414333



- Copy to:-1. Medical Health Officer, NDMC, Palika Kendra, Sansad Marg, New Delhi-01.
2 .M/S Public Affair Restaurant (A Unit of RVN Hospitality) located at Flat No.67 & 68 (1st & 2nd floors), Khan Market, New Delhi-110003.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

N/L
INSPECTION REPORT

1. Name & address of the building : M/S Public Affair Restaurant (A Unit of RVN Hospitality) located at Flat No.67 & 68(1st & 2nd floors), Khan Market, New Delhi-110003.
2. Building is comprised of : G+2(Restaurant at 1st & 2nd floor). Ground floor other's property.
3. Type of Occupancy : Eating House.
4. Type of Case : New Case
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 10.10.2015.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Navneet Kalra (Partner).
10. Year of Construction : 1982.
11. Applicant's letter No : No.MOH/653/C.S.I(Lic)/D/SI-VI, dated 15.09.15.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	6m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	02nos.	02nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	.		
	Upper Floor	90cm(each)	90 to 95cms.(each)	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	01no.	MR
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	two exits	two exits	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguisher			
	Total numbers	04 nos.	06 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers on each floor	01no.	01no.	MR
	Length of hose reel hose	30m.	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	Required	Provided	MR
	Hooters	N.A.	Provided	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	Provided	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	Provided	MR
	Number of hydrants per floor	01no.	Provided	MR
	Hose Box	01no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450+180LPM	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000Liters.	10000Liters.	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided 10Kva Generator set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

 20/10/15

Signature of the Inspecting Officer

Name Vedpal

Designation ADO