

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/S/2015/W2/2016-01

Dated: 01/01/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Bal Bharati Public School, Unit-II(Primary Wing) At Block- B (Except Auditorium Block) Pitam Pura, Delhi – 110034**. comprised of Basement +Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/MS/DFS/2011/1842 Dated 04-08-2011**. The premises was re inspected by the officer concerned of this department on 23-11-2015 in the presence of **Mr Garg (Adm Officer)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 17-01-2011/NBC and that the premises is fit for occupancy class "Educational" Group B with effect from 01/01/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...01/01/16..... at New Delhi by.

  
Santokh Singh)  
Chief Fire Officer  
PH 011-23414250

Copy to:

1. The Principal,  
Bal Bharati Public School,  
Unit-II Block- B, Pitam Pura,  
Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The auditorium block shall not be used for any purpose till compliance of the shortcomings is made and FSC is issued by this department.

N/13  
INSPECTION REPORT

1. Name & address of the building: Bal Bharati Public School, Unit II, Parwana Road, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Educational (B Blocks =Basement + Ground + 3 Upper Floors) Except Block C.
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1842 Dated 04-08-2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2000/1074 Dated 21/06/00
6. Date of inspection : 23-11-2015
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
  - a. from the building side : A garg (Estate Manager)
9. Year of Construction : 1999
10. Applicant's letter No. : 8734/BBPS/2015 Dated 13-10-2015

No. of Students=1850
No. of class rooms=46
Plot area=6475m <sup>2</sup>
Covered area=6500m <sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive Issued	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	Number of staircases			
	• Upper floors	4	Provided	MR
	• Basements	2	Provided	MR
	g. Width of staircases			
	• Upper floors	4x1.5m	Old case(4x148cm)	MR
	• Basements	2x150cm	Provided	MR
	h. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	i. No of continuous staircase to terrace			
	j. Width Of Corridor	NA	NA	NA
	k. Door Size	100cm	Provided(All the class Rooms having more than 45 students have 2 Doors)	MR

N/14

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	38 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided ✓	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	Provided ✓	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	• Basements Upper Floor	Required	Provided	MR
		NA	NA ✓	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100mm	Provided ✓	MR
	• Number of hydrants per floor	Required	Provided ✓	MR
	• Hose Box	required	Provided ✓	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

7/15

13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	1x900lpm & 1x180 lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	100000ltrs	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	Provided	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

N/16

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/1842 Dated 04-08-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer ~~1/3~~ 20/11/2015

Name Uday Vire Singh

Designation ADO/WP

Signature of the Inspecting

Name

Designation