

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/MS/DFS/EH/2015/ 521 12

Dated: 01/01/16

**FIRE SAFETY CERTIFICATE**

Certified that the Band Stand (A unit of City one Cafe & Bar Pvt. Ltd.)(Formerly D'Destitation) located at Unit No.214- 216, Second Floor, DDA Commercial Complex, Aurbindo Palace, Hauz Khas, New Delhi-110016.comprised of Basement, Ground + Two Upper Floors. The restaurant is running at second floor only was granted FSC by this department vide letter No.F6/DFS/MS/EH/2013/160 dated 09/01/2013.The premises was re-inspected by the officer concerned of this department on 21/12/15 in the presence of Mr. Pappu and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D Assembly Building (**Restaurant**) with effect from ~~01/01/16~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~01/01/16~~ at New Delhi by.

  
**(Dr. G. C. Misra)**  
**Chief Fire Officer**  
Tel: 011-23414333

Copy to: -

(1) Dy. Health Officer,  
SDMC, South Zone,  
Aurbindo Marg, Green Park New Delhi.

(2) Mr. Noorul Arfeen  
Band Stand  
Unit No.214- 216, Second Floor, DDA Commercial Complex, Aurbindo Palace,  
Hauz Khas, New Delhi-110016.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



N14

**INSPECTION REPORT**

1. Name & address of the building:- Band Stand (A unit of City one Cafe & Bar Pvt. Ltd.)(Formerly D'Destitation), Unit No. 214- 216, Second Floor, DDA Commercial Complex, Aurbindo Palace, Hauz Khas, New Delhi-110016.
2. Type of occupancy:- Group – D, Assembly Building, ( Restaurant)
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2013/160 dated 09/01/13
5. Fire safety directives No.- Nil
6. Date of inspection:-21 /12/15
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Pappu
9. Year of construction:- 1985
10. Applicant's letter No:-DHO/SZ/2015/D/2835 dated 01/12/15 & party letter no. nil dt.02/12/15
11. Composition of building :- Basement,Ground plus Two Upper Floors.

The restaurant is running at 2<sup>nd</sup> floor of a building.

(old case)

Sl. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirement NBC	Provided at Site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	12 m	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits:</b>			
	A. Number of staircases			
	1. Upper floors	02nos	Provided 02nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25mtrs	1.42m & 1.25m each	MR (Old Case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01no	Provided 02 nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtrs.	2mtr & 1.08m (old case)	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Provided	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	12 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	Required	Provided	MR
	2) Length of hose reel hose	30 mm	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

22



415

7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	NR	Smoke detector provided	MR
	2) Location of main panel	NR	Kitchen	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided DG Set	MR
	5) Hooter's Location	Required	Near Centre & Entrance	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided 01 no each floor	MR
	3) Hose box	Required	Provided	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	<b>1) Ground level</b>			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	<b>2) Terrace level</b>			
	a) Discharge of pump	450 Lpm	Provided 600 lpm	MR
	b) Head of pump	35m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltrs.	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided DG set	MR
18.	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A

N/6

19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the restaurant were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/EH/2013/160 Dated: 09/01/2013 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

22/12/2015

Signature of the inspecting officer  
Name :- D.B. Mukherjee.  
Designation :- Assitt. Div. Officer(BCP).

28/1/15

20/1/15