

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/DFS/MS/Auditorium/2015/ M02/2268

Dated : 31/12/15

FIRE SAFETY CERTIFICATE

Certified that the **FICCI Auditorium** located at **Federation House, Tansen Marg, New Delhi**, comprised of **Basement & Ground floor only , basement – storage/services & ground floor-auditorium** was granted FSC by this department vide letter No.F6/DFS/MS/2012/**Auditorium/2459** dated **10/07/2012**. The premise was re-inspected by the officer concerned of this department on **12/12/15** in the presence of **Mr. Rajbir & Mr. Vikas** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group A-1** with effect from 31/12/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 31/12/15 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23414333

- Copy to: (1) The Joint Commissioner of Police (Lic.),
1st Floor, Police Station, Defence Colony, New Delhi.
- (2) FICCI Auditorium,
Federation House, Tansen Marg, New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

- N/A9 -

INSPECTION REPORT

1. Name & address of the building:- FICCI Auditorium, Federation House, Tansen Marg, New Delhi.
2. Type of occupancy:- Auditorium / Assembly
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/Auditorium2012/2459 dated 10/07/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 12/12/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O Manoj Kumar Sharma
8. Name & designation of officer
From the building side:- Mr. Rajbir & Mr. Vikas
9. Year of construction:- 1984-85
10. Applicant's letter No:- dated 18/09/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	12 mtr.	MR
	2) Gate width	N/A	05 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 no.	02 no.	MR
	2. Basements	03 no.	03 no.	MR
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	1.45 mtr. & 1.70 mtr. + 01 ramp	MR
	2. Basements	1.50 mtr.	1.50 mtr. , 1.60 mtr. & 1.70 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR

h

mew

- 7/90 -

	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	24 Nos.	30 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	06 no.	06 no.	MR
	2) Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	3) Nozzle diameter	5 mm.	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke/Beam	Smoke/Beam	MR
	2) Location of main panel	G.floor	G.floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	Near the gate	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System / Intercom	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	06 nos.	06 nos.	MR
	3) Hose box	06 nos	06 nos	MR
12.	Yard Hydrants			
	1) Total number of hydrants	10 Nos	10 Nos	MR
	2) Hose box	10 Nos	10 Nos	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 Mtr.	70 Mtr.	MR
	c) Number of main pump	01 No	01No.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	40 Mtr.	40 Mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A

h

m

- N/A -

	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,50000Ltr.	1,50000Ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan			
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The shortcomings communicated by this department vide letter dated 03/08/15 found rectified.

The fire protection system provided in the Auditorium were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/Auditorium/2012/2459 dated 10/07/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Gurmukh Singh
Divisional Officer

Manoj Kumar Sharma
Assistant Divisional Officer



Dy CPO (NDZ)

21/12