

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/dfs/ms/eh/2015/w2/13

Dated: 04/01/2016


FIRE SAFETY CERTIFICATE

Certified that the M/s 4TH Dimension Fine Dine & Lounge (A Unit of Mans Entertainment) located at A-19, Vishal Enclave Rajouri Garden, New Delhi on Ground & First Floor of a premise comprised of B+stilt+G+1st + 2nd & 3rd floors owned/occupied by M/s 4TH Dimension Fine Dine & Lounge (A Unit of Mans Entertainment) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 04-12-2015 in the presence of Mr. Sunny Khanna (Partner) and that the building/premises is fit for occupancy Assembly with effect from 04.01.16.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used only as per NBC part-IV.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on 04/01/16.....at New Delhi by


(Santokh Singh)
Chief fire Officer
Ph.011-23414250

Copy to:

1. M/s 4TH Dimension Fine Dine & Lounge (A Unit of Mans Entertainment) located at Ground & First Floor, A-19, Vishal Enclave Rajouri Garden, New Delhi
2. Dy. Health Officer West Zone, Vishal Enclave, Rajouri Garden, New Delhi-110027

Basement = Storage
 Ground, 1st floor = Restaurant
 Restaurant - 2nd 3rd floor
 Stilt = Parking

INSPECTION REPORT

1. Name & address of the building : M/s 4TH Dimension Fine Dine & Lounge (A Unit of Mans Entertainment) located at A-19, Vishal Enclave Rajouri Garden, New Delhi on Ground & First Floor.
2. Type of Occupancy : Assembly
3. Type of Case : New ✓
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 04-12-2015
7. Name of the Inspecting Officers : DO (West) & ADO (MN)
8. Name and designation of officers :
 From the building side : Mr. Sunny Khanna (Partner)
9. Year of Construction : 2009
10. Applicant's letter No. : D-1902/HD/WZ dated 16/9/2015 ✓

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	M/R
	• Gate width	4.5 mtr	On Main Road ✓	M/R
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	3	M.R.
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1 mtr	150 cm, 135 cm & 112cm Provided ✓	M/R
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	1	2	MR
	e. Width of Corridor	1.5 mtr	Halls only	M.R.
	f. Door size	2 m & 1m	Provided on both floors	M.R.
3.	Compartmentation.			

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	08	10	M.R.
	• Types	CO ₂ , Water CO ₂ type	Provided	M.R.
	• IS marking	ISI marked	Provided	M.R.
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	M.R.
	• Length of hose reel hose	30 m required	Provided	M.R.
	• Nozzle diameter	5 mm	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	M.R.
	• Location of Main Panel	Required	Provided	M.R.
	• Location of Repeater Panel	Required	Provided	M.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	Required	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System	N.R.	Provided	M.R.
10.	Automatic Sprinkler system			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.R.	Provided	N.R.
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	150 m. m	Provided	M.R.
	• Number of hydrants per floor	01	Provided	M.R.
	• Hose Box	01	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.

	Hose Box	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	NA	2280 LPM	NA
	➤ Head of Main pump	NA	60 mtr	NA
	➤ Number of main pumps	NA	01	NA
	➤ Jockey Pump out put	NA	180 LPM	NA
	➤ Jockey pump head	NA	60 mtr.	NA
	➤ Standby pump out put	NA	2280 LPM	NA
	➤ Standby pump Head	NA	60 mtr	NA
	➤ Auto Starting/Manual stopping	NA	Provided	NA
	➤ Pump Hose Access	NA	Provided	NA
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	50,000 litres	M.R.
	➤ Draw -off connection	NA	Provided	M.R.
	➤ Fire service inlet	NA	Provided	M.R.
	➤ Access to tank	NA	Provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R	N.R	N.R

2/4

	➤ Location	N.R	N.R	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Name: Muckesh Verma

Designation ADO (M.V.)

Signature of the Inspection Officer

Name Sunil Chaudhary

Designation DO (H)