

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. *F6/DFS/MS/2016/52/64*

Dated: *07/01/16*

FIRE SAFETY CERTIFICATE

Certified that M/S B.P.Shanti Path Service Station (Retail Outlet of Petroleum Class A & B Belonging to Bharat Petroleum Corporation Ltd.), at Shanti Path, Moti Bagh, New Delhi- 110021, comprised of ground plus one upper floor, owned/occupied by Bharat Petroleum Corporation Limited, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2012/4089, dated 01-11-2012. The premises was re-inspected by the officer concerned of this department on 02-01-2016 in the presence of Mrs. Huma Faruque Ali (COCO Officer-BP Green Park) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class Storage (Petrol Pump and Service Station) with effect from *07/01/2016* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *07/01/2016* at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-1. Dr. P.K.Sharma, Medical Health Officer, NDMC, Palika Kendra, New Delhi. *etc*

2. M/S B.P.Shanti Path Service Station (Retail Outlet of Petroleum Class A & B Belonging to Bharat Petroleum Corporation Ltd.), at Shanti Path, Moti Bagh, New Delhi-110021.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S B.P.Shanti Path Service Station(Retail Outlet of Petroleum Class A & B Belonging to Bharat Petroleum Corporation Ltd.), at Moti Bagh, New Delhi-110021.
2. Building is comprised of : Ground plus one upper floor only.
3. Type of Occupancy : Storage Occupancy (Patrol Pump).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2012/4089, Dated 01.11.2012.
6. Fire Safety direction letter No :No.F5/(12)/DFS/BP/2007/245, Dated 18.05.2007.
7. Date of Inspection : 02.01.2016.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Mrs. Huma Faruque Ali (COCO Officer-BP Green Park)
10. Year of Construction : 2010.
11. Applicant's letter No : DRT/.BP Shanti Path, dated 19.12.2015.

S.No	Minimum Standards on fire prevention and fire safety as per Rules	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	30 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
h. Door Size	1 m	1m	MR	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	Exhaust fans Provided	MR
5	Fire Extinguisher			
	Total numbers	14 nos.	17 nos.	MR
	Types	CO ₂ & ABC,DCP, AFFF	CO ₂ DCP,ABC, AFFF Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01no.	01no.	MR
	Length of hose reel hose	30m	30m	MR
	Nozzle diameter	6mm	6mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.


10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	35m	35m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Liters	5000Liters	MR
15	No Smoking Signage.(Hindi & English)	Required	Provided in Hindi And English	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided DG Set 50KVA	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.

M/S B.P.Shanti Path Service Station at Moti Bagh, New Delhi-110021.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No: F6/DFS/MS/2012/4089, dated 01.11.2012, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.

 31/1/16

Signature of the Inspecting Officer

Name: Vedpal

Designation: ADO

D.O.(South) = C/L

Dy.C.F.O. (S.Z)
