

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/EH/2016/WZ/66

Dated: 07/01/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Carls Jr.** located at **Second Floor – 15 & 16, Pacific Mall Khayala, Community Centre, Najafgarh Road, Khayala, New Delhi. – 110027.** FSC to mall is issued vide letter no. F6/DFS/MS/2014/WZ/345 dated 11-03-2014. The premises owned/ occupied by **M/s Carls Jr.** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 10-12-2015 in the presence of Mr. Sanjay Pandey and found that the said building premises is fit for occupancy class “Assembly” Group D with effect from 07/01/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/01/16..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer,  
Ph:011-23414250.

Copy to:

1. Carls Jr., Second Floor – 15 & 16,  
Pacific Mall Khayala, Community Centre, Najafgarh Road,  
Khayala, New Delhi. – 110027.
2. Dy. Health Officer,  
SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

N/1

1. Name & address of the building: Carls Jr. located at Second Floor – 15 & 16, Pacific Mall Khayala, Community Centre, Najafgarh Road, Khayala, New Delhi. – 110027.
2. Type of Occupancy : Assembly
3. Type of Case : New (Situating in Mall already issued NOC vide letter no. F6/DFS/MS/2014/WZ/345 dated 11-03-2014)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 10-12-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer  
from the building side : Sh. Sanjay Pandey
9. Year of Construction : 2015
10. Applicant's letter No. : D-2284/HD/WZ dated 29-10-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits: common with the mall			
	a. Number of staircases			
	• Upper floors	2	Provided by mall	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5	Provided by mall	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA



N/2

	<ul style="list-style-type: none"> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06 nos. each type DCP & CO <sub>2</sub> ISI marked	10 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke Required NA Required Required	Provided Provided NA Provided Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Not Applicable Required Required	Not Applicable Provided Provided	Not Applicable MR MR
11.	Internal Hydrants: Common with the mall			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements: Common with the mall			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> </ul>	NA NA NA NA NA NA NA NA	Common with the mall Common with the mall Common with the mall Common with the mall Common with the mall Common with the mall Common with the mall Common with the mall	NA NA NA NA NA NA NA NA



N/3

➤ Pump House Access	NA	Common with the mall	NA
• Terrace level			
➤ Discharge of pump	900 lpm	Common with the mall	MR
➤ Head of the pump	40 m	Common with the mall	MR
➤ Power supply	Required	Common with the mall	MR
➤ Auto starting of pump	Required	Common with the mall	MR
14. Captive water Storage for fire fighting: Common with the mall			
• Under ground tank capacity	NA	2.00.000 litres	NA
➤ Draw off connection	NA	Provided	NA
➤ Fire service inlet	Required	Provided	MR
➤ Access to tank	NA	Provided	NA
• Overhead Tank capacity	10, 000 litres	30, 000 Litres	MR
15. Exit Signage	Required	Provided	MR
16. Provision of lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17. Standby power supply	Required	Provided	MR
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Mukesh Verma

Name

Designation Add(MN)

Designation

DO (West)

24/12/10