

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2016/M92/83

Dated: 11/01/16

FIRE SAFETY CERTIFICATE

Certified that the Mc. Donald Family Restauraotr at shop no. 98 & 107,V3S Mall,Plot No.123,Laxmi Nagar District Centre,Vikas Marg,Delhi being run ground floor of the building was granted FSC by this department vide letter no. F6/DFS/MS/EH/2012/2506 Dated 11.07.12. The premises was re-inspected by the concerned of this department on dated 21.12.15 in the presence of Sh.Kanwalbeer Singh (Manager) have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and found that the premises is fit for occupancy class D 'Assembly (Eating House/Restaurant)' with effect from11/01/16 for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....11/01/16.....at New Delhi by


(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Dy. Health Officer,
East Delhi Municipal Corporation ,Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

Copy to-
Sh.Harish Sharma,
Cannaught Plaza Restaurant Pvt.Ltd.
13-A Jor Bagh Market,New Delhi-110003

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Mc Donalds Restaurant at Shop no.98 &107, Mall no.12 Laxmi Nagar, District Centre, Delhi.
2. Type of Occupancy : Assembly(Restaurant)
3. Type of Case : Renewal
4. Details of Previous FSC : F6/DFS/MS/EH/2012/2506 dated 11.07.12
5. Fire Safety directives No. : NBC
6. Date of Inspection : 21.12.2015
7. Name of the Inspecting officers : ADO R.K. Yadav
8. Name and designation of officer from the building side : Sh.Kanwalbeer Singh (Manager)
9. Year of Construction : 2004
10. Applicant's letter No. : CPRPL/FM/NOC/2013-14/226 Dated- 05.10.15

| N O. | Minimum Standards on fire prevention and fire safety U/R33 | NBC Requirement | Provided at Site | Remarks |
|------|---|-----------------|----------------------------|---------|
| 1 | Access to building | 12 Mtrs. | 26 Mtrs. | MR |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | 4.5Mtrs. | 4.5Mtrs. | MR |
| | | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper Floor • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper Floor • Basement | N/A | N/A | N/A |
| | c. Protection of exits | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | g. Width of Corridor | 2.5Mtr. | 2.5Mtr | MR |
| | h. Door Size | 2.0 Mtr | 3 Nos(1,0 M,2.0 M & .80 M) | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper floor | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • types | 03 Nos. | 05Nos. | MR |
| | | ABC & Co2 | ABC & Co2 | MR |
| | <ul style="list-style-type: none"> • IS marking | ISI marked | ISI marked | MR |

| | | | | |
|----|---|--------------------|--------------------------|-----|
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | 1No. | Provided | MR |
| | • Length of hose reel hose | 30 Mtr | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | Heat & Smoke | Provided | MR |
| | • Location of main panel | Control Room | 1 st basement | MR |
| | • Location of repeater panel | Security Room | Provided | MR |
| | • Alternate source of power | Battery & DG Set | Provided | MR |
| | • Hooter's location | Different Location | Different Location | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | Required | Provided | MR |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | N/A | N/A | N/A |
| | • size of riser/down-comer | 100mm | 100mm | MR |
| | • Number of hydrants per floor | 1no. | 1no. | MR |
| | • Hose Box | 1no. | 1no. | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | Not Required | 1no. | MR |
| | • Hose Box | Not Required | 1no. | MR |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | Required | Provided | MR |
| | ➤ Discharge of main Pump | 2850LPM | 2850LPM | MR |
| | ➤ Head of Main Pump | 60Mtrs | 60Mtrs | MR |
| | ➤ Number of main pumps | 1nos. | 1nos. | MR |
| | ➤ Jockey pump out put | 180LPM | 180LPM | MR |
| | ➤ Jockey pump head | 60Mtrs | 60Mtrs | MR |
| | ➤ Standby pump out put | 2850LPM | 2850LPM | MR |
| | ➤ Standby pump Head | 60Mtrs | 60Mtrs | MR |
| | ➤ Auto Starting /Manual stopping | Auto | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the Pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | 2,00,000Ltrs | 2,00,000Ltrs | MR |
| | ➤ Draw-off connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 30000 Ltrs. | 30000 Ltrs. | MR |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|--|----------|----------|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | Required | 1000KVA | MR |
| 18 | Refuge Area. | N/A | N/A | N/A |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | Required | Provided | MR |
| | • Flow switch panel | Required | Provided | MR |
| | • PA system panel | Required | Provided | MR |
| | • Battery backup | Required | Provided | MR |
| | • Building Floor Plans | Required | Provided | MR |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were test checked and found not functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. :F.6/DFS/MS/EH/2016/2506 Dated 11.07.12 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name: R.K. Yadav
Designation: ADO(LN)

R. K. Yadav
4/11/2016

DO (ED) Submitted for approval please

By CFD (NDR)

Vinay
5/11/16