

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

(SEE SUB -RULE (1) OF RULE 35)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/SH/2016/W2/95 Dated 13/1/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Foundry (A Unit of Flying Hospitality LLP) located at F-84, First Floor, Industrial Pocket, Distt. Centre, Rajouri Garden, New Delhi in a building comprised of Basement + Ground + 3 Upper Floors owned / occupied by M/s. Foundry (A Unit of Flying Hospitality LLP) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 17.12.2015 in the presence of Sh. Amardeep Singh Kohli (Director) and found that the said premises is fit for occupancy class "Assembly" Group D with effect from 13/1/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Issued on 13/1/16 at New Delhi by



(Santokh Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. M/s Foundry (A Unit of Flying Hospitality LLP) located at F-84, First Floor, Industrial Pocket, Distt. Centre, Rajouri Garden, New Delhi
2. Dy. Health Officer, West Zone,SDMC, Public Health Department, Vishal Enclave. New Delhi.

Following fire safety directives must be adhered to:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the / construction etc. shall be verified by the concerned building sanctioning agency.
5. The certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' (sub rule (1) of rule 37) along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs. Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)

OK
my

The said premises M/s Foundry (A Unit of Flying Hospitality LLP) is located on first floor of the building comprised of Basement + Ground + 03 Upper Floors. The basement is currently empty, Ground floor is having restaurant, first floor is having the said restaurant, second floor is office and third floor is empty.

INSPECTION REPORT

1. Name & address of the building: M/s Foundry (A Unit of Flying Hospitality LLP) located at F -- 84, First Floor, Industrial Pocket, Distt. Centre, Rajouri Garden, New Delhi.
2. Type of Occupancy : Assembly on first floor only in a building comprised of Basement + G + 3 Upper Floors.
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 17-12-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Amardeep Singh Kohli (Director)
9. Year of Construction : 2015
10. Applicant's letter No. : D - 1660/HD/WZ dated 01-09-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 & 1 m	155 cm & 104 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1m	Provided	MR
3.	Compartmentation			

	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	➤ Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	10000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

cfo/2268
23/12/15



Signature of the Inspecting Officer
Mukesh Verma
Designation
ADD (MN)

Signature of the Inspecting Officer
Name
Designation