

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

NO.

FG/DFB/MST/EH/2016/52/109

Dated:

15/01/16

FIRE SAFETY CERTIFICATE

Certified that M/S "SANA-DI-GE" Restaurant (A Unit of Goldfinch Hotels Pvt. Ltd), located at, 22/48, Commercial Complex, Malcha Marg, Chankyapuri, New Delhi, comprised of basement(Storage only), ground plus two upper floors owned/occupied by Goldfinch Hotels Pvt. Ltd, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on dated 02.01.2016 in the presence of Sh.Trishul Kumar, Site Incharge and that the building is fit for occupancy class "Eating House" with effect from15/01/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on.....15/01/.....2016 at New Delhi by



(Dr. G.C.Misra)

Chief Fire Officer

T.No.011-23414333

- Copy to:- 1. Dr. P.K.Sharma, Medical Officer of Health, NDMC, Palika Kendra, New Delhi-110001. etc
h
2. Sh. K.P.Shetty, Director, M/S "SANA-DI-GE" Restaurant (A Unit of Goldfinch Hotels Pvt. Ltd), 22/48, Commercial Complex, Malcha Marg, Chankyapuri, New Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S "SANA-DI-GE" Restaurant)(A Unit of A Unit of Goldfinch Hotel Pvt. Ltd), 22/48, Commercial Complex, Malcha Marg, Chankyapuri, New Delhi.
2. Building is comprised of : B+G+2.
3. Type of Occupancy : Eating House.
4. Type of Case : New Case. (Earlier it was in the name of M/S "SCHENGEN").
5. Details of Previous NOC : No.F6/DFS/MS/EH/2014/SZ/1272, Dated 10.10.2014.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 02.01.2016.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Trishul Kumar (Site Incharge).
10. Year of Construction : 1982.
11. Applicant's letter No : No.MOH/D-713/(Lic.)/SI-X, Dated 03.12.15.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	6m	9 m	MR
	Gate width	2m	2m & 1.25m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	02nos.	02nos+1no from 1 st Floor to 2 nd floor.	MR	
	02nos.	02nos	MR	
	1.5m	1.5, 1m & 1m from 1 st To 2 nd floor.	MR	
	1.5m	1.5m & 90cm	MR	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	01no.	01no.	MR	
	N.A.	N.A.	N.A.	
2m	2m & 1,25m	MR		
3	Compartmentation			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.	N.A.	
	Required	Provided	MR	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
4	Smoke Management System.			
Basement Upper floor	30a/c per hour	Exhaust fan provided	MR	
	12 a/c per hour	Exhaust fan provided	MR	
5	Fire Extinguisher			
Total numbers types IS marking	08 nos.	08 nos.	MR	
	CO ₂ & ABC	CO ₂ & ABC	MR	
	ISI marked	ISI marked	MR	
6	First-aid-Hose Reels.			
Total numbers on each floor	01no.	Provided at ground	MR	

7	Automatic fire detection and alarming system.			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	Location of main panel	Reception	Reception	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	Provided at ground & 1 st floor only(cover All areas)	MR
	Hose Box	01no.	Provided at ground & 1 st floor only	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900LPM	900LPM	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A	N.A	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000Liters.	10000Liters.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.

N/7

M/S "SANA-DI-GE" Restaurant, 22/48, Commercial Complex, Malcha Marg, Chankyapuri.

19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.


The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for kind consideration and necessary approval please.


Signature of the Inspecting Officer

Name Vedpal
Designation ADO

D.O.(South) = 9/2
DyCFO (S2) 
5/1/16