

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/DFS/MS/SZ/Ind./2016/

123

Dated:

18/01/16

FIRE SAFETY CERTIFICATE

Certified that M.G.Motors. located at, Z-37, Okhla Industrial Area Phase-II, New Delhi comprised of basement, ground, mezzanine and 02 upper floors, owned / occupied by TATA Motors was granted FSC by this department vide letter No. F6/DFS/MS/Industrial/2011/3412 dated 09.12.2011. The premises was re-inspected by the officer concerned of this department on 04/01/2016 in the presence of Mr. Prashant and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class- G, Industrial Building(Moderate Hazard) with effect from ~~18/01/16~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~18/01/16~~ at New Delhi by


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Dr. G. C. Misra
Chief Fire Officer

Copy to: -

Mr. Ajay Sanghi (Partner)
M G Motors,
Z-37, Okhla Industrial Ph-II,
New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per the provisions of BBL.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- M G Motors, Z-37, Okhla Industrial Area Phase-II, New Delhi
2. Type of occupancy:- Group G Industrial Building
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/Industrial/2011/3412 dated: 09/12/2011
5. Fire safety directives No.- F.6/DFS/MS/BP/2010/803 dated:-16/03/2010
6. Date of inspection:- 04/01/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Prashant
9. Year of construction:- 2011
10. Applicant's letter No:- Nil Dated 27/11/2015
11. Composition of building: - basement, ground, mezzanine and two upper floors.

Sl. No	Minimum Standards on fire Prevention and fire safety under U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	24mtr	MR
	2) Gate width	Required	5mtr	MR
	3) Width of internal road	Required	15ft	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02no.	Provided 2nos	MR
	2. Basements	02nos	Provided 2 nos, & one ramp	MR
	B. Width of staircase			
	1. Upper floors	1.50m	1.50m each	MR
	2. Basements	1.50m	1.50mtr each & Ramp 2.84m	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	02 nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	20 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01nos	Provided 01nos	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke & heat Provided	MR
	2) Location of main panel	Required	Entrance	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150mm	Provided	MR
	2) Number of hydrants per floor	1nos	Provided	MR
	3) Hose box	1nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided 04nos	MR
	2) Hose box	Required	Provided 04nos	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280LPM	2280LPM	MR
	b) Head of main pump	55mtr	55mtr	MR
	c) Number of main pump	Required	02nos	MR
	d) Jockey pump out put	180LPM	180LPM	MR
	e) Jockey pump head	55mtr	55mtr	MR
	f) Stand by pump output	2280LPM	2280LPM	MR
	g) Stand by pump head	55mtr	55mtr	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900Lpm	Provided	MR
	b) Head of pump	35m	35m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	1,00,000ltr	1,00,000ltr	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lift			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A

N/12

19	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/Industrial/2011/3412 dated 09/12/2011, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pls.

[Signature]
6/11/2016

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

[Signature]
20 (Smt)

[Signature]
6/11/16