

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No.F6/MS/DFS/Audi/2016/ 52/120

Dated: 18/01/16

FIRE SAFETY CERTIFICATE

Certified that Main Auditorium, Mini Auditorium I & II located at Baha'I House of Worship, Bahapur, Kalkaji, New Delhi-110019 comprised of ground floor only owned/occupied by Baha'I House of Worship was issued FSC by this department vide letter no. F6/DFS/MS/2012/Audi/4361 dated 23/11/2013. The building was re-inspected by the officer concerned of this department on 06/01/2016 in presence of Mr. Shaheen Javid and found that the said premises have complied with the fire prevention and fire safety requirements that the building is fit for occupancy class "Assembly Building Group -D" with effect from the date of issue ... 18/01/16..... of this certificate for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 18/01/16 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to: -

Mr. Shaheen Javid (General Manager)
Main Auditorium, Mini Auditorium I & II, Baha'I House of Worship,
Bahapur, Kalkaji, New Delhi-110019.

7c by ADO (BSP)

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Main Auditorium, Mini Auditorium I & II at Baha'I House Of Worship, Bahapur, Kalkaji, New Delhi-110019
2. Type of occupancy:- Assembly Building Group-D,
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/2012/Audi/4361 dated 23/11/2013
5. Fire safety directives No.- Nil
6. Date of inspection:- 06/01/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Shaheen Javid
9. Year of construction:- 1994
10. Applicant's letter No:- Nil dated 29/10/2015
11. Composition of building :- ground floor.(Three auditorium) seating capacity of auditorium is Main - 408,Mini audi-1=70,Mini audi-II=70

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	12m	MR
	2) Gate width	Required	Provided	MR
	3)Width of internal road	Required	Provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2mtr	Provided 06 nos. in main audi. & 02nos. each in mini audi	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Provided	MR

✓


5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	16 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02no.	Provided 02nos	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke	MR
	2) Location of main panel	Required	Near Entry	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	UPS Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150mm	Provided	MR
	2) Number of hydrants per floor	2nos	Provided	MR
	3) Hose box	2nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1620LPM	1620LPM	MR
	b) Head of main pump	55mtr	55mtr	MR
	c) Number of main pump	2nos	Provided	MR
	d) Jockey pump out put	180LPM	180LPM	MR
	e) Jockey pump head	55mtr	55mtr	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A

14. Captive Water Storage for Fire Fighting


	1) Under ground tank capacity	1,00,000ltr	1,00,000ltr	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000ltr	20,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	D.G.Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, renewal of the FSC issued vide letter No. F6/DFS/MS/2012/Audi/4361 dated 23/11/2013, under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for sign pl.


 Signature of the inspecting officer
 Name: - D.B. Mukherjee.
 Designation:- Assistant Divisional Officer (BCP)

DO (Genl)


 11/11/16