

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/Indell/2016/S2/142

Dated: 20/01/16

FIRE SAFETY CERTIFICATE

Certified that M/S Munna Lal Ram Dayal, Plot No. A-188, Okhla Industrial Area, Phase-1, New Delhi-110020, comprised of basement, ground plus two upper floors owned/occupied by M/S Munna Lal Ram Dayal, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Ind./2013/384, dated 24-01-13. The premises was re-inspected by the officer concerned of this department on 15-01-2016 in the presence of Sh. V.S.Negi, Chief Associate and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class G "Industrial building" with effect from20/01/...2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Issued on....20/01/.... 2016 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- Sh. Gaurav Khandelwal, Partner, M/S Munna Lal Ram Dayal, Plot No. A-188, Okhla Industrial Area, Phase-1, New Delhi-110020. 

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

N/6
INSPECTION REPORT

1	Name & address of the building	M/S Munna Lal Ram Dayal, Plot No. A-188, Okhla Industrial Area, Phase-1, New Delhi-110020.		
2	Type of Occupancy	Industrial G		
3	Building comprised of	Basement, Ground plus two upper floors.		
4	Type of case	Renewal		
5	Details of previous NOC	No.F6/DFS/MS/Ind./2013/384, Dated 24.01.13.		
6	Fire safety directives letter No	F.6/DFS/MS/BP/2010/1038, Dated 12.04.2010.		
7	Date of inspection	15.10.2015.		
8	Name of the inspecting Officers	: ADO Vedpal		
9	Name and designation of officers from the building side	Sh. V.S.Negi (Chief Associate).		
10	Year of construction	2010		
11	Applicant's letter No.	Nil	Dt. 28.12.2015	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks / NMR MR
1	Access to building			
	1) Road width	9 mtrs	Provided	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	02nos.	02nos.	MR
	2. basements	02nos.	02nos.	MR
	b. Width of staircase			
	1. Upper floors	1.5 mtrs(each)	1.5m (each)	MR
	2. basements	1.5 mtrs(each)	1.5m (each)	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02nos.	02nos.	MR
	e. Width of corridor	Not Required	Not Required	MR
	f. Door size	1.25m	1.25m (each)	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Not Required	Not Required	N/A
	4. water curtain	Not Required	Not Required	N/A
	5. Fire dampers	Required	Required	MR
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	Exhaust Fan Provided	MR
	upper floors		Mech. Ventinational	MR
5	Fire Extinguishers			
	total numbers		15 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	location of Main Panel	Ground Floor	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	All Areas	All Areas	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A

(Handwritten signature)

N/7

10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	total number of hydrants	04nos.	04nos.	MR
	hose box	04nos.	04nos.	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280 LPM	2280 LPM	MR
	b. Head of main pump	70 Mtr	70m	MR
	c. Number of main pumps	One	Provided	MR
	d. jockey pump out put	180 LPM	180 LPM	MR
	e. jockey pump head	70 Mtr	70m	MR
	f. Standby Pump output	2280 LPM	2280LPM	MR
	g. Stanby Pump head	70 Mtr	70m	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900 LPM	900 LPM	MR
	b. head of the pump	40 mtr	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire			
	1. Underground tank capacity	100000 ltr	Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20,000 ltr	20000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.		No lift provided	
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 flooding system provided for server room.			

N/8

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/Ind./2013/384, dated 24.01.2013 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.




15/1/16

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

~~D.O. (South)~~



18/1/16