

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/School/2016/NDZ/1167

Dated: 25/1/16

FIRE SAFETY CERTIFICATE

Certified that the Mother Mary's School (Earlier Queen Mary's School) at Sahkarita Marg, Mayur Vihar -1, Delhi-91, owned/occupied by Mother Mary's School, comprised of basement ground plus three upper floors was granted fire safety certificate vide letter no.F6/DFS/MS/School/2012/2401 dated 05.07.12. The School building was inspected by the officer concerned of this department on 20.01.16 in the presence of Smt.Sujata Choudhary (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the B+GF+FS+SF+TF of building is fit for occupancy Group B "Educational Building" with effect from 25.1.16..... for a period of three years, subject to conditions printed overleaf.

Issued on ... 25.1.16..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
The Manager  
Mother Mary's School (Earlier Queen Mary's School)  
Sahkarita Marg, Mayur Vihar -1, Delhi-91

Copy to:-  
The Dy. Director of Education  
D-Block, Anand Vihar, Delhi.

C/c  
lls

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per B.B.L.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building : Mother Mary's School( Queen Mary School) at Sahkarita Marg, Mayur Vihar Ph-I, Delhi
2. Building is comprised of : B+G+3
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/Schoolk/2012/2401 dated 5/01/16
6. Fire Safety direction letter No : F6/MS/DFS/BP/2004/468 dtd. 27.02.2004
7. Date of Inspection : 20.01.16
8. Name of the Inspecting Officers: : ADO R.K.Yadav
9. Name of the designation of Officer from the building side : Smt.Sujata Choudhary (Principal)
10. Year of Construction : 2005
11. Applicant's letter No : MM/2015/2612 dtd.19/01/16

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	36 m	MR
	Gate width	4.5 m	5.5 m	MR
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	4 no.	MR
	Basement	2 no.	2 no.	MR
	B. Width of Staircases			
	Upper Floor	1.5 M	1.4, 1.48, 1.4 & 1.37 m	MR
	Basement	1.5 m	1.4 m, 1.4 m	MR
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	4 no.	4 no.	MR
g. Width of Corridor	1.5 m	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	12a/c per hour	N.A	N.A


N/14

5.	Fire Extinguisher	22 no.	24 no.	MR
	Total numbers	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	types	ISI marked	ISI marked	MR
	IS marking			
6	First-aid-Hose Reels.	02 no.	02 no.	MR
	Total numbers of each floor	30 m	30 m	MR
	Length of hose reel hose	5 mm	5 mm	MR
	Nozzle diameter			
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	N.A	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	02 no.	02 no.	MR
	Hose Box	02 no.	02 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A.
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Required	MR
	➤ Auto Starting of pump	Auto	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 Liters	20,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. F.6/DFS/MS/School/2011/3148 dated 24.11.2011 renewal under Rule 35 of Delhi Fire Service Rules 2010 is recommended.

  
Signature of the Inspecting Officer | 20/11/2016  
Name:-R.K.Yadav  
Designation:-ADO (LN)

DO(ED) Submitted for approval please.

Dy CFO (MSZ)

Vinay  
20/11/16