

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2016/M02/171

Dated 25/1/16

FIRE SAFETY CERTIFICATE

Certified that the Raj Mahal Banquet Hall, at 2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi comprised of second floor owned/occupied by M/s Raj Mahal Banquet & Hotels Pvt.Ltd, was granted FSC by this department vide letter No. F6/DFS/MS/2012/3232 dated 05.09.2012. The Premises was re-inspected by the officer concerned of this department on 20.01.2016 in the presence of Sh.Sushil Kumar(Accountant)of the Banquet and found that the Banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the Banquet hall at second floor is fit for occupancy class "Assembly (Banquet hall)" with effect from 25/1/16..... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on.....25/1/16.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

o/c
PK

To

The Manager,
Raj Mahal Banquet Hall
2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,Health Department, Shahdara South Zone,
Karkardooma, Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
- 6 This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 8 Basement shall be used as per BBL

INSPECTION REPORT

1. Name & address of the building : Raj Mahal Banquet Hall, at 2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi
2. Type of Occupancy : **Assembly**
3. Type of Case : **Renewal**
4. Details of Previous FSC : F.6/DFS/MS/2012/3232 dated 05.09.2012
5. Fire Safety directives No : F.6/DFS/MS/2012/2698 dated 24.07.2012
6. Date of Inspection : 20.01.2016
7. Name of the Inspecting Officer : ADO Suresh Singh
8. Name of the designation of Officer
From the building side : Sh. Sushil Kumar (Accountant)
9. Year of Construction : 2005
10. Applicant's letter No : 11.01.2016

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs 4.5 Mtrs. NA	26 Mtrs. 5 Mtrs. NA	MR MR NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	03 Nos 03 Nos	03 Nos. 03 Nos.	MR MR
	B. Width of Staircases	1.5 M	1.5 M	MR
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M 1.5 M	1.5 M 1.5 M	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Provided	MR MR
	e. No. of continuous staircases to terrace	1 Nos.	2 Nos.	MR
	g. Width of Corridor	2 Mtrs	2.5 Mtrs	MR
	h. Door Size	2.0 Mtr.	3 no. of 2 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required Required 2 hrs. NA Required	Provided Sealed 2 hrs. NA Provided	MR MR MR NA MR
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	30a/c per hour 12 a/c per hour	provided --do--	MR MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 no. ABC & Co2 ISI marked	06 No. ABC & Co2 ISI marked	MR MR MR

N/11

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor 	4 no.	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Heat & smoke	Provided	MR
	<ul style="list-style-type: none"> Location of main panel 	Control Room	1 st basement	MR
	<ul style="list-style-type: none"> Location of repeater panel 	Security Room	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Battery & DG Set	Provided	MR
	<ul style="list-style-type: none"> Hooters's location 	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> basement 	Required	Provided in entre basement	MR
	<ul style="list-style-type: none"> upper floor 	Required	Provided	MR
	<ul style="list-style-type: none"> sprinkler above false ceiling 	Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	04 nos.	04 nos.	MR
	<ul style="list-style-type: none"> Hose Box 	04 nos.	04 nos.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	3 nos.	3 nos.	MR
	<ul style="list-style-type: none"> Hose Box 	3 nos.	3 nos.	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of Main Pump 	60 Mtrs.	60 mtrs	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	1 nos.	1 nos.	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	60 Mtrs.	60 mtrs.	MR
	<ul style="list-style-type: none"> ➤ Standby pump out put 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> ➤ Standby pump Head 	60 Mtrs	60 Mtrs.	MR
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping 	Auto	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA

N/12

14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000 Ltrs.	25000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	provided	MR
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	1000 KVA	MR
18	Refuge Area.			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	----do----	MR
	• PA system panel	Required	----do----	MR
	• Batter backup	Required	----do----	MR
	• Building Floor Plans	Required	----do---	MR
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/2012/3232 dated 05.09.2012 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Singh
21.1.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

Submitted for approval please.

By CFO (NO2)

Vingr
21/1/16